## PHILIPPINE BIDDING DOCUMENTS

# Procurement of INFRASTRUCTURE PROJECTS

Government of the Republic of the Philippines

Renovation of Sanitary System of DSWD-CAR Training Center Compound

Sixth Edition July 2020

#### **Preface**

These Philippine Bidding Documents (PBDs) for the procurement of Infrastructure Projects (hereinafter referred to also as the "Works") through Competitive Bidding have been prepared by the Government of the Philippines for use by all branches, agencies, departments, bureaus, offices, or instrumentalities of the government, including government-owned and/or -controlled corporations, government financial institutions, state universities and colleges, local government units, and autonomous regional government. The procedures and practices presented in this document have been developed through broad experience, and are for mandatory use in projects that are financed in whole or in part by the Government of the Philippines or any foreign government/foreign or international financing institution in accordance with the provisions of the 2016 revised Implementing Rules and Regulations (IRR) of Republic Act (RA) No. 9184.

The PBDs are intended as a model for admeasurements (unit prices or unit rates in a bill of quantities) types of contract, which are the most common in Works contracting.

The Bidding Documents shall clearly and adequately define, among others: (i) the objectives, scope, and expected outputs and/or results of the proposed contract; (ii) the eligibility requirements of Bidders; (iii) the expected contract duration; and (iv)the obligations, duties, and/or functions of the winning Bidder.

Care should be taken to check the relevance of the provisions of the PBDs against the requirements of the specific Works to be procured. If duplication of a subject is inevitable in other sections of the document prepared by the Procuring Entity, care must be exercised to avoid contradictions between clauses dealing with the same matter.

Moreover, each section is prepared with notes intended only as information for the Procuring Entity or the person drafting the Bidding Documents. They shall not be included in the final documents. The following general directions should be observed when using the documents:

- a. All the documents listed in the Table of Contents are normally required for the procurement of Infrastructure Projects. However, they should be adapted as necessary to the circumstances of the particular Project.
- b. Specific details, such as the "name of the Procuring Entity" and "address for bid submission," should be furnished in the Instructions to Bidders, Bid Data Sheet, and Special Conditions of Contract. The final documents should contain neither blank spaces nor options.
- c. This Preface and the footnotes or notes in italics included in the Invitation to Bid, BDS, General Conditions of Contract, Special Conditions of Contract, Specifications, Drawings, and Bill of Quantities are not part of the text of the final document, although they contain instructions that the Procuring Entity should strictly follow.
- d. The cover should be modified as required to identify the Bidding Documents as to the names of the Project, Contract, and Procuring Entity, in addition to date of issue.

- e. Modifications for specific Procurement Project details should be provided in the Special Conditions of Contract as amendments to the Conditions of Contract. For easy completion, whenever reference has to be made to specific clauses in the Bid Data Sheet or Special Conditions of Contract, these terms shall be printed in bold typeface on Sections I (Instructions to Bidders) and III (General Conditions of Contract), respectively.
- f. For guidelines on the use of Bidding Forms and the procurement of Foreign-Assisted Projects, these will be covered by a separate issuance of the Government Procurement Policy Board.

## TABLE OF CONTENTS

Gl	ossar	y of Terms, Abbreviations, and Acronyms	5
Sec	ction	I. Invitation to Bid	7
Sec	ction	II. Instructions to Bidders	10
	1.	Scope of Bid	11
	2.	Funding Information	11
	3.	Bidding Requirements	11
	4.	Corrupt, Fraudulent, Collusive, Coercive, and Obstructive Practices	11
	5.	Eligible Bidders	12
	6.	Origin of Associated Goods	12
	7.	Subcontracts	12
	8.	Pre-Bid Conference	12
	9.	Clarification and Amendment of Bidding Documents	12
	10.	Documents Comprising the Bid: Eligibility and Technical Components	13
	11.	Documents Comprising the Bid: Financial Component	13
	12.	Alternative Bids	13
	13.	Bid Prices	13
	14.	Bid and Payment Currencies	14
	15.	Bid Security	14
	16.	Sealing and Marking of Bids	14
	17.	Deadline for Submission of Bids	14
	18.	Opening and Preliminary Examination of Bids	14
	19.	Detailed Evaluation and Comparison of Bids	15
	20.	Post Qualification	15
	21.	Signing of the Contract	15
Sec	ction	III. Bid Data Sheet	16
Sec	ction	IV. General Conditions of Contract	19
	1.	Scope of Contract	20
	2.	Sectional Completion of Works	20
	3.	Possession of Site	20
	4.	The Contractor's Obligations	20
	5.	Performance Security	21
	6.	Site Investigation Reports	21

7.	Warranty	21
8.	Liability of the Contractor	21
9.	Termination for Other Causes	21
10.	Dayworks	22
11.	Program of Work	22
12.	Instructions, Inspections and Audits	22
13.	Advance Payment	22
14.	Progress Payments	22
15.	Operating and Maintenance Manuals	22
Section	V. Special Conditions of Contract	23
Section	VI. Specifications	25
	VII. Drawings	
	VIII. Bill of Quantities	
Section	IX. Checklist of Technical and Financial Documents	J1

## Glossary of Terms, Abbreviations, and Acronyms

**ABC** – Approved Budget for the Contract.

**ARCC** – Allowable Range of Contract Cost.

**BAC** – Bids and Awards Committee.

**Bid** – A signed offer or proposal to undertake a contract submitted by a bidder in response to and in consonance with the requirements of the bidding documents. Also referred to as *Proposal* and *Tender*. (2016 revised IRR, Section 5[c])

**Bidder** – Refers to a contractor, manufacturer, supplier, distributor and/or consultant who submits a bid in response to the requirements of the Bidding Documents. (2016 revised IRR, Section 5[d])

**Bidding Documents** – The documents issued by the Procuring Entity as the bases for bids, furnishing all information necessary for a prospective bidder to prepare a bid for the Goods, Infrastructure Projects, and/or Consulting Services required by the Procuring Entity. (2016 revised IRR, Section 5[e])

**BIR** – Bureau of Internal Revenue.

**BSP** – Bangko Sentral ng Pilipinas.

**CDA** – Cooperative Development Authority.

Consulting Services – Refer to services for Infrastructure Projects and other types of projects or activities of the GOP requiring adequate external technical and professional expertise that are beyond the capability and/or capacity of the GOP to undertake such as, but not limited to: (i) advisory and review services; (ii) pre-investment or feasibility studies; (iii) design; (iv) construction supervision; (v) management and related services; and (vi) other technical services or special studies. (2016 revised IRR, Section 5[i])

Contract – Refers to the agreement entered into between the Procuring Entity and the Supplier or Manufacturer or Distributor or Service Provider for procurement of Goods and Services; Contractor for Procurement of Infrastructure Projects; or Consultant or Consulting Firm for Procurement of Consulting Services; as the case may be, as recorded in the Contract Form signed by the parties, including all attachments and appendices thereto and all documents incorporated by reference therein.

**Contractor** – is a natural or juridical entity whose proposal was accepted by the Procuring Entity and to whom the Contract to execute the Work was awarded. Contractor as used in these Bidding Documents may likewise refer to a supplier, distributor, manufacturer, or consultant.

**CPI** – Consumer Price Index.

**DOLE** – Department of Labor and Employment.

**DTI** – Department of Trade and Industry.

**Foreign-funded Procurement or Foreign-Assisted Project** – Refers to procurement whose funding source is from a foreign government, foreign or international financing institution as specified in the Treaty or International or Executive Agreement. (2016 revised IRR, Section 5[b]).

**GFI** – Government Financial Institution.

**GOCC** – Government-owned and/or –controlled corporation.

Goods – Refer to all items, supplies, materials and general support services, except Consulting Services and Infrastructure Projects, which may be needed in the transaction of public businesses or in the pursuit of any government undertaking, project or activity, whether in the nature of equipment, furniture, stationery, materials for construction, or personal property of any kind, including non-personal or contractual services such as the repair and maintenance of equipment and furniture, as well as trucking, hauling, janitorial, security, and related or analogous services, as well as procurement of materials and supplies provided by the Procuring Entity for such services. The term "related" or "analogous services" shall include, but is not limited to, lease or purchase of office space, media advertisements, health maintenance services, and other services essential to the operation of the Procuring Entity. (2016 revised IRR, Section 5[r])

**GOP** – Government of the Philippines.

**Infrastructure Projects** – Include the construction, improvement, rehabilitation, demolition, repair, restoration or maintenance of roads and bridges, railways, airports, seaports, communication facilities, civil works components of information technology projects, irrigation, flood control and drainage, water supply, sanitation, sewerage and solid waste management systems, shore protection, energy/power and electrification facilities, national buildings, school buildings, hospital buildings, and other related construction projects of the government. Also referred to as *civil works or works*. (2016 revised IRR, Section 5[u])

**LGUs** – Local Government Units.

**NFCC** – Net Financial Contracting Capacity.

**NGA** – National Government Agency.

**PCAB** – Philippine Contractors Accreditation Board.

**PhilGEPS** - Philippine Government Electronic Procurement System.

**Procurement Project** – refers to a specific or identified procurement covering goods, infrastructure project or consulting services. A Procurement Project shall be described, detailed, and scheduled in the Project Procurement Management Plan prepared by the agency which shall be consolidated in the procuring entity's Annual Procurement Plan. (GPPB Circular No. 06-2019 dated 17 July 2019)

**PSA** – Philippine Statistics Authority.

**SEC** – Securities and Exchange Commission.

**SLCC** – Single Largest Completed Contract.

**UN** – United Nations.

### Section I. Invitation to Bid

#### **Notes on the Invitation to Bid**

The Invitation to Bid (IB) provides information that enables potential Bidders to decide whether to participate in the procurement at hand. The IB shall be posted in accordance with Section 21.2 of the 2016 revised IRR of RA No. 9184.

Apart from the essential items listed in the Bidding Documents, the IB should also indicate the following:

- a. The date of availability of the Bidding Documents, which shall be from the time the IB is first advertised/posted until the deadline for the submission and receipt of bids;
- b. The place where the Bidding Documents may be acquired or the website where it may be downloaded;
- c. The deadline for the submission and receipt of bids; and
- d. Any important bid evaluation criteria.

The IB should be incorporated into the Bidding Documents. The information contained in the IB must conform to the Bidding Documents and in particular to the relevant information in the Bid Data Sheet.





#### **Invitation to Bid for**

# Renovation of Sanitary System of DSWD FO-CAR Training Center

1. The **Department of Social Welfare and Development Field Office- Cordillera Administrative Region**, through the **General Appropriations Act of 2025** intends to apply the sum of *One Million One Hundred Sixteen Thousand Thirty Pesos and Ninety Three Centavos only (PhpP 1,116,030.93*) being the Approved Budget for the Contract (ABC) to payments under the contract for *ITB-2025-DSWD-CAR 05*.

Item #	Description	Approved Budget for the Contract
1	Renovation of Sanitary System of DSWD FO-CAR Training Center Compound - General Requirement - Sanitary/Plumbing Works - Civil Works/Site Works - Others - Architectural Works - Construction Safety	₱1,116,030.93
	- Electrical Works and Health	

Bids received in excess of the ABC shall be automatically rejected at bid opening.

- 2. The **Department of Social Welfare and Development Field Office-CAR** now invites bids for the above Procurement Project. Completion of the Works is required within **Seventy (70) Calendar Days upon receipt of Notice to Proceed**. Bidders should have completed a contract similar to the Project. The description of an eligible bidder is contained in the Bidding Documents, particularly, in Section II (Instructions to Bidders).
- 3. Bidding will be conducted through open competitive bidding procedures using non-discretionary "pass/fail" criteria as specified in the 2016 revised Implementing Rules and Regulations (IRR) of Republic Act (RA) No. 9184.
  - Bidding is restricted to Filipino citizens/sole proprietorships, partnerships, or organizations with at least sixty percent (60%) interest or outstanding capital stock belonging to citizens of the Philippines, and to citizens or organizations of a country the laws or regulations of which grant similar rights or privileges to Filipino citizens, pursuant to RA No. 5183.
- 4. Interested bidders may obtain further information from the **Department of Social Welfare and Development-CAR** and inspect the Bidding Documents at the address given below from **8:00AM to 5:00PM**, Monday to Friday
- 5. A complete set of Bidding Documents may be acquired by interested bidders on *April* 17, 2025 to 1:00PM (PST) May 6, 2025 from given address and website/s below. The bidding document fee costs PhP 5,000.00.

The Procuring Entity allows payment of bidding documents through Bank-to-Bank transaction. However, the Official Receipt shall only be issued to the upon receipt of proof of payment by the Cash Section with the following bank details:





**Account Number- 0222-0218-63** 

Account NameName of Bank
DSWD FO CAR (MISC TRUST ACCOUNT)
Landbank of the Philippines- Baguio Branch

- 6. The **Department of Social Welfare and Development Field Office-CAR** will hold a Pre-Bid Conference<sup>1</sup> on **1:30PM of April 24, 2025** at **DSWD-CAR Premises** and/or via **google meet** with a meeting ID/Link *meet.google.com/yop-dbdp-fnd* which shall be opened to prospective bidders.
- 7. Bids must be duly received by the BAC Secretariat via manual submission at the office address as indicated below, on or before 1:00PM (PST) of May 6, 2025. Late bids shall not be accepted.
- 8. All bids must be accompanied by a bid security in any of the acceptable forms and in the amount stated in **ITB** Clause 15.
- 9. Bid opening shall be on **1:30PM (PST) of May 6, 2025** at the given address below and/or through *meet.google.com/mhv-srhd-vpn*. Bids will be opened in the presence of the bidders' representatives who choose to attend the activity.
- 10. The **Department of Social Welfare and Development Field Office-CAR** reserves the right to reject any and all bids, declare a failure of bidding, or not award the contract at any time prior to contract award in accordance with Sections 35.6 and 41 of the 2016 revised Implementing Rules and Regulations (IRR) of RA No. 9184, without thereby incurring any liability to the affected bidder or bidders.
- 11. For further information, please refer to:

#### **BAC SECRETARIAT**

Procurement Section DSWD-CAR #40 Northdrive, Baguio City bacsec.car@dswd.gov.ph (074) 661-0430 Local 25123

Mobile Number: Smart 0969-5729-176

12. You may visit the following websites for downloading the Bidding Documents: <a href="https://car.dswd.gov.ph/downloads/procurement-opportunities">https://car.dswd.gov.ph/downloads/procurement-opportunities</a>

ORIGINAL SIGNED ENGR. ENRIOUE H. GASCON.JR.

**BAC Chairperson** 

.

May be deleted in case the ABC is less than One Million Pesos (PhP1,000,000) where the Procuring Entity may not hold a pre-bid conference.





## Section II. Instructions to Bidders

#### **Notes on the Instructions to Bidders**

This Section on the Instruction to Bidders (ITB) provides the information necessary for bidders to prepare responsive bids, in accordance with the requirements of the Procuring Entity. It also provides information on bid submission, eligibility check, opening and evaluation of bids, post-qualification, and on the award of contract.





#### 1. Scope of Bid

The Procuring Entity, **Department of Social Welfare and Development Field Office- CAR** invites Bids for the **Renovation of Sanitary System of DSWD-CAR Training Center**, with Project Identification Number **ITB 2025- DSWD-CAR 05**.

The Procurement Project (referred to herein as "Project") is for the construction of Works, as described in Section VI (Specifications).

#### 2. Funding Information

- 2.1. The GOP through the source of funding as indicated below for CY 2025 in the amount of *One Million One Hundred Sixteen Thousand Thirty Pesos & Ninety Three Centavos (PhP 1,116,030.93)*.
- 2.2. The source of funding is:
  - a. NGA, the General Appropriations Act or Special Appropriations.

#### 3. Bidding Requirements

The Bidding for the Project shall be governed by all the provisions of RA No. 9184 and its 2016 revised IRR, including its Generic Procurement Manual and associated policies, rules and regulations as the primary source thereof, while the herein clauses shall serve as the secondary source thereof.

Any amendments made to the IRR and other GPPB issuances shall be applicable only to the ongoing posting, advertisement, or invitation to bid by the BAC through the issuance of a supplemental or bid bulletin.

The Bidder, by the act of submitting its Bid, shall be deemed to have inspected the site, determined the general characteristics of the contracted Works and the conditions for this Project, such as the location and the nature of the work; (b) climatic conditions; (c) transportation facilities; (c) nature and condition of the terrain, geological conditions at the site communication facilities, requirements, location and availability of construction aggregates and other materials, labor, water, electric power and access roads; and (d) other factors that may affect the cost, duration and execution or implementation of the contract, project, or work and examine all instructions, forms, terms, and project requirements in the Bidding Documents.

#### 4. Corrupt, Fraudulent, Collusive, Coercive, and Obstructive Practices

The Procuring Entity, as well as the Bidders and Contractors, shall observe the highest standard of ethics during the procurement and execution of the contract. They or through an agent shall not engage in corrupt, fraudulent, collusive, coercive, and obstructive practices defined under Annex "I" of the 2016 revised IRR of RA No. 9184 or other integrity violations in competing for the Project.





#### 5. Eligible Bidders

- 5.1. Only Bids of Bidders found to be legally, technically, and financially capable will be evaluated.
- 5.2. The Bidder must have an experience of having completed a Single Largest Completed Contract (SLCC) that is similar to this Project, equivalent to at least fifty percent (50%) of the ABC adjusted, if necessary, by the Bidder to current prices using the PSA's CPI, except under conditions provided for in Section 23.4.2.4 of the 2016 revised IRR of RA No. 9184.

A contract is considered to be "similar" to the contract to be bid if it has the major categories of work stated in the **BDS**.

- 5.3. For Foreign-funded Procurement, the Procuring Entity and the foreign government/foreign or international financing institution may agree on another track record requirement, as specified in the Bidding Document prepared for this purpose.
- 5.4. The Bidders shall comply with the eligibility criteria under Section 23.4.2 of the 2016 IRR of RA No. 9184.

#### 6. Origin of Associated Goods

There is no restriction on the origin of Goods other than those prohibited by a decision of the UN Security Council taken under Chapter VII of the Charter of the UN.

#### 7. Subcontracts

a. Subcontracting is not allowed.

#### 8. Pre-Bid Conference

The Procuring Entity will hold a pre-bid conference for this Project on the specified date and time and either at its physical address on **April 24, 2025 at 1:30PM (PST)** and/or through videoconferencing/webcasting **meet.google.com/yop-dbdp-fnd** as indicated in paragraph 8 of the **IB.** 

#### 9. Clarification and Amendment of Bidding Documents

Prospective bidders may request for clarification on and/or interpretation of any part of the Bidding Documents. Such requests must be in writing and received by the Procuring Entity, either at its given address or through electronic mail indicated in the **IB**, at least ten (10) calendar days before the deadline set for the submission and receipt of Bids.





## 10. Documents Comprising the Bid: Eligibility and Technical Components

- 10.1. The first envelope shall contain the eligibility and technical documents of the Bid as specified in **Section IX. Checklist of Technical and Financial Documents**.
- 10.2. If the eligibility requirements or statements, the bids, and all other documents for submission to the BAC are in foreign language other than English, it must be accompanied by a translation in English, which shall be authenticated by the appropriate Philippine foreign service establishment, post, or the equivalent office having jurisdiction over the foreign bidder's affairs in the Philippines. For Contracting Parties to the Apostille Convention, only the translated documents shall be authenticated through an apostille pursuant to GPPB Resolution No. 13-2019 dated 23 May 2019. The English translation shall govern, for purposes of interpretation of the bid.
- 10.3. A valid PCAB License in case of Joint Ventures, and registration for the type and cost of the contract for this Project. Any additional type of Contractor license or permit shall be indicated in the **BDS**.
- 10.4. A List of Contractor's key personnel (e.g., Project Manager, Project Engineers, Materials Engineers, and Foremen) assigned to the contract to be bid, with their complete qualification and experience data shall be provided. These key personnel must meet the required minimum years of experience set in the **BDS**.
- 10.5. A List of Contractor's major equipment units, which are owned, leased, and/or under purchase agreements, supported by proof of ownership, certification of availability of equipment from the equipment lessor/vendor for the duration of the project, as the case may be, must meet the minimum requirements for the contract set in the **BDS**.

#### 11. Documents Comprising the Bid: Financial Component

- 11.1. The second bid envelope shall contain the financial documents for the Bid as specified in **Section IX. Checklist of Technical and Financial Documents**.
- 11.2. Any bid exceeding the ABC indicated in paragraph 1 of the **IB** shall not be accepted.
- 11.3. For Foreign-funded procurement, a ceiling may be applied to bid prices provided the conditions are met under Section 31.2 of the 2016 revised IRR of RA No. 9184.

#### 12. Alternative Bids

Bidders shall submit offers that comply with the requirements of the Bidding Documents, including the basic technical design as indicated in the drawings and specifications. Unless there is a value engineering clause in the **BDS**, alternative Bids shall not be accepted.

#### 13. Bid Prices

All bid prices for the given scope of work in the Project as awarded shall be considered as fixed prices, and therefore not subject to price escalation during contract





implementation, except under extraordinary circumstances as determined by the NEDA and approved by the GPPB pursuant to the revised Guidelines for Contract Price Escalation guidelines.

#### 14. Bid and Payment Currencies

- 14.1. Bid prices may be quoted in the local currency or tradeable currency accepted by the BSP at the discretion of the Bidder. However, for purposes of bid evaluation, Bids denominated in foreign currencies shall be converted to Philippine currency based on the exchange rate as published in the BSP reference rate bulletin on the day of the bid opening.
- 14.2. Payment of the contract price shall be made in:
  a. Philippine Peso.

#### 15. Bid Security

- 15.1. The Bidder shall submit a Bid Securing Declaration or any form of Bid Security in the amount indicated in the **BDS**, which shall be not less than the percentage of the ABC in accordance with the schedule in the **BDS**.
- 15.2. The Bid and bid security shall be valid within *120 Calendar Days* upon opening of bids. Any bid not accompanied by an acceptable bid security shall be rejected by the Procuring Entity as non-responsive.

#### 16. Sealing and Marking of Bids

#### Each Bidder shall submit one copy of the first and second components of its Bid.

The Procuring Entity may request additional hard copies and/or electronic copies of the Bid. However, failure of the Bidders to comply with the said request shall not be a ground for disqualification.

If the Procuring Entity allows the submission of bids through online submission to the given website or any other electronic means, the Bidder shall submit an electronic copy of its Bid, which must be digitally signed. An electronic copy that cannot be opened or is corrupted shall be considered non-responsive and, thus, automatically disqualified.

#### 17. Deadline for Submission of Bids

The Bidders shall submit on the specified date and time and either at its physical address or through online submission as indicated in paragraph 7 of the **IB**.

#### 18. Opening and Preliminary Examination of Bids

18.1. The BAC shall open the Bids in public at the time, on the date, and at the place specified in paragraph 9 of the **IB**. The Bidders' representatives who are present shall sign a register evidencing their attendance. In case videoconferencing, webcasting or other similar technologies will be used, attendance of participants shall likewise be recorded by the BAC Secretariat.





In case the Bids cannot be opened as scheduled due to justifiable reasons, the rescheduling requirements under Section 29 of the 2016 revised IRR of RA No. 9184 shall prevail.

18.2. The preliminary examination of Bids shall be governed by Section 30 of the 2016 revised IRR of RA No. 9184.

#### 19. Detailed Evaluation and Comparison of Bids

- 19.1. The Procuring Entity's BAC shall immediately conduct a detailed evaluation of all Bids rated "passed" using non-discretionary pass/fail criteria. The BAC shall consider the conditions in the evaluation of Bids under Section 32.2 of 2016 revised IRR of RA No. 9184.
- 19.2. If the Project allows partial bids, all Bids and combinations of Bids as indicated in the **BDS** shall be received by the same deadline and opened and evaluated simultaneously so as to determine the Bid or combination of Bids offering the lowest calculated cost to the Procuring Entity. Bid Security as required by **ITB** Clause 15 shall be submitted for each contract (lot) separately.
- 19.3. In all cases, the NFCC computation pursuant to Section 23.4.2.6 of the 2016 revised IRR of RA No. 9184 must be sufficient for the total of the ABCs for all the lots participated in by the prospective Bidder.

#### 20. Post Qualification

Within a non-extendible period of five (5) calendar days from receipt by the Bidder of the notice from the BAC that it submitted the Lowest Calculated Bid, the Bidder shall submit its latest income and business tax returns filed and paid through the BIR Electronic Filing and Payment System (eFPS), and other appropriate licenses and permits required by law and stated in the **BDS**.

#### 21. Signing of the Contract

The documents required in Section 37.2 of the 2016 revised IRR of RA No. 9184 shall form part of the Contract. Additional Contract documents are indicated in the **BDS**.

#### Section III. Bid Data Sheet

#### **Notes on the Bid Data Sheet (BDS)**

The Bid Data Sheet (BDS) consists of provisions that supplement, amend, or specify in detail, information, or requirements included in the ITB found in Section II, which are specific to each procurement.

This Section is intended to assist the Procuring Entity in providing the specific information in relation to corresponding clauses in the ITB and has to be prepared for each specific procurement.

The Procuring Entity should specify in the BDS information and requirements specific to the circumstances of the Procuring Entity, the processing of the procurement, and the bid evaluation criteria that will apply to the Bids. In preparing the BDS, the following aspects should be checked:

- a. Information that specifies and complements provisions of the ITB must be incorporated.
- b. Amendments and/or supplements, if any, to provisions of the ITB as necessitated by the circumstances of the specific procurement, must also be incorporated.

## **Bid Data Sheet**

ITB Clause					
5.2	For this purpose, contracts similar to the Project refer to contracts which have the same major categories of work, which shall be:  **Construction/Improvement of Building Sanitary System**				
7.1	Not Applicable				
10.3	PCAB license should be at least "small b" as to size range and/or at least C or D as to license category				
The Key Personnel must meet the required minimum years of experience set bel					
	Key Personnel	General Experience	Relevant Experience		
	Project Engineer	at least 3 years in civil works	at least 2 years in project supervision of vertical structures of at least 3-storey in height		
	Sanitary Engineer/ Master Plumber	at least 2 years in Plumbing & Sanitary Works in Structures	at least 2 years in supervision of Plumbing & Sanitary Works on vertical structures of at least 3-storey in height		
10.4	Safety Officer	at least 2 years in Safety Management	at least 2 years in building construction		
	Project Foreman	at least 2 years in Building Construction	At least 2 years in building construction of at least 3-storey in height		
	Welder	At least 2 years as Welder & TESDA Accredited	At least 2 years as Welder		
	Key personnel should be o	equipped with appropriate li	cense and/or documents		

	The minimum majo	or equipment requiremen	ts are the following:
	Equipment	Capacity	Number of Units
	1. Mini Dump Truck	at least 2 cubic meter	at least one (1)
	2. Speed Cutter	14 inches	at least one (1)
	3. Bar Bender		at least one (1)
10.5	4. Welding Machine	300 amps	at least one (1)
10.5	5.Concrete Vibrator		at least one (1)
	6. One Bagger Concrete		at least one (1)
	Mixer		
	7. Jackhammer		at least one (1)
12	Not Applicable	1 0 0 0 0 0	5 1 1
	•		ng Declaration or any of the
	following forms and amounts		Thousand Thusa Handwad
15.1		•	<b>Thousand, Three Hundred</b> (2%) of ABC], if bid security
13.1			draft/guarantee or irrevocable
	letter of credit;	simanager s eneck, came	draft guarantee of interocusie
	,		
	> The amount of not less than <b>Fifty Five Thousand</b> , <b>Eight Hundred Pesos</b>		
	only <b>PhP 55,800.</b>	<b>00</b> or (5%) of ABC] if bid s	security is in Surety Bond.
19.2	Not Applicable		
20.2	In support to the Statement of all ongoing government and private contracts, the following documents shall be submitted as part of the post qualification requirement  1. Notice of Award and/or Contracts/Purchase Order  2. Notice to Proceed (for government transactions only under public bidding)		
	In support to the statement of Single Largest Completed Contracts (SLCC) the following documents shall be submitted as part of the post qualification requirement:		
	1.Statement of Single Largest Completed Contracts (SLCC) shall be supported with End-user's acceptance or Official Receipts or Sales Invoice 2. In case a Collection Receipt is available in lieu of Official Receipt, such should be		
	supported with the necessary 3. Certificate of Inspection significant (BGMS)	<u> </u>	
21	laws and/or the Procuring Ent schedule, construction method	ity, such as construction sch ls, equipment utilization scl	nat maybe required by existing nedule and S-curve, manpower hedule, construction safety and acceptable tools of project
	the contractor is required to which shall be the reckon	submit a Statement of Wing document for any p	ny approved work extension, ork Accomplished as of date, benalties but not limited to age that may be applicable

## Section IV. General Conditions of Contract

#### **Notes on the General Conditions of Contract**

The General Conditions of Contract (GCC) in this Section, read in conjunction with the Special Conditions of Contract in Section V and other documents listed therein, should be a complete document expressing all the rights and obligations of the parties.

Matters governing performance of the Contractor, payments under the contract, or matters affecting the risks, rights, and obligations of the parties under the contract are included in the GCC and Special Conditions of Contract.

Any complementary information, which may be needed, shall be introduced only through the Special Conditions of Contract.

#### 1. Scope of Contract

This Contract shall include all such items, although not specifically mentioned, that can be reasonably inferred as being required for its completion as if such items were expressly mentioned herein. All the provisions of RA No. 9184 and its 2016 revised IRR, including the Generic Procurement Manual, and associated issuances, constitute the primary source for the terms and conditions of the Contract, and thus, applicable in contract implementation. Herein clauses shall serve as the secondary source for the terms and conditions of the Contract.

This is without prejudice to Sections 74.1 and 74.2 of the 2016 revised IRR of RA No. 9184 allowing the GPPB to amend the IRR, which shall be applied to all procurement activities, the advertisement, posting, or invitation of which were issued after the effectivity of the said amendment.

#### 2. Sectional Completion of Works

If sectional completion is specified in the **Special Conditions of Contract** (SCC), references in the Conditions of Contract to the Works, the Completion Date, and the Intended Completion Date shall apply to any Section of the Works (other than references to the Completion Date and Intended Completion Date for the whole of the Works).

#### 3. Possession of Site

- 3.1 The Procuring Entity shall give possession of all or parts of the Site to the Contractor based on the schedule of delivery indicated in the SCC, which corresponds to the execution of the Works. If the Contractor suffers delay or incurs cost from failure on the part of the Procuring Entity to give possession in accordance with the terms of this clause, the Procuring Entity's Representative shall give the Contractor a Contract Time Extension and certify such sum as fair to cover the cost incurred, which sum shall be paid by Procuring Entity.
  - 3.2 If possession of a portion is not given by the above date, the Procuring Entity will be deemed to have delayed the start of the relevant activities. The resulting adjustments in contract time to address such delay may be addressed through contract extension provided under Annex "E" of the 2016 revised IRR of RA No. 9184.

#### 4. The Contractor's Obligations

The Contractor shall employ the key personnel named in the Schedule of Key Personnel indicating their designation, in accordance with **ITB** Clause 10.3 and specified in the **BDS**, to carry out the supervision of the Works.

The Procuring Entity will approve any proposed replacement of key personnel only if their relevant qualifications and abilities are equal to or better than those of the personnel listed in the Schedule.

#### 5. Performance Security

- 5.1. Within ten (10) calendar days from receipt of the Notice of Award from the Procuring Entity but in no case later than the signing of the contract by both parties, the successful Bidder shall furnish the performance security in any of the forms prescribed in Section 39 of the 2016 revised IRR.
- 5.2. The Contractor, by entering into the Contract with the Procuring Entity, acknowledges the right of the Procuring Entity to institute action pursuant to RA No. 3688 against any subcontractor be they an individual, firm, partnership, corporation, or association supplying the Contractor with labor, materials and/or equipment for the performance of this Contract.

#### 6. Site Investigation Reports

The Contractor, in preparing the Bid, shall rely on any Site Investigation Reports referred to in the SCC supplemented by any information obtained by the Contractor.

#### 7. Warranty

- 7.1. In case the Contractor fails to undertake the repair works under Section 62.2.2 of the 2016 revised IRR, the Procuring Entity shall forfeit its performance security, subject its property(ies) to attachment or garnishment proceedings, and perpetually disqualify it from participating in any public bidding. All payables of the GOP in his favor shall be offset to recover the costs.
- 7.2. The warranty against Structural Defects/Failures, except that occasioned-on force majeure, shall cover the period from the date of issuance of the Certificate of Final Acceptance by the Procuring Entity. Specific duration of the warranty is found in the **SCC**.

#### 8. Liability of the Contractor

Subject to additional provisions, if any, set forth in the SCC, the Contractor's liability under this Contract shall be as provided by the laws of the Republic of the Philippines.

If the Contractor is a joint venture, all partners to the joint venture shall be jointly and severally liable to the Procuring Entity.

#### 9. Termination for Other Causes

Contract termination shall be initiated in case it is determined *prima facie* by the Procuring Entity that the Contractor has engaged, before, or during the implementation of the contract, in unlawful deeds and behaviors relative to contract acquisition and implementation, such as, but not limited to corrupt, fraudulent, collusive, coercive, and obstructive practices as stated in **ITB** Clause 4.

#### 10. Dayworks

Subject to the guidelines on Variation Order in Annex "E" of the 2016 revised IRR of RA No. 9184, and if applicable as indicated in the SCC, the Dayworks rates in the Contractor's Bid shall be used for small additional amounts of work only when the Procuring Entity's Representative has given written instructions in advance for additional work to be paid for in that way.

#### 11. Program of Work

- 11.1. The Contractor shall submit to the Procuring Entity's Representative for approval the said Program of Work showing the general methods, arrangements, order, and timing for all the activities in the Works. The submissions of the Program of Work are indicated in the **SCC**.
- 11.2. The Contractor shall submit to the Procuring Entity's Representative for approval an updated Program of Work at intervals no longer than the period stated in the SCC. If the Contractor does not submit an updated Program of Work within this period, the Procuring Entity's Representative may withhold the amount stated in the SCC from the next payment certificate and continue to withhold this amount until the next payment after the date on which the overdue Program of Work has been submitted.

#### 12. Instructions, Inspections and Audits

The Contractor shall permit the GOP or the Procuring Entity to inspect the Contractor's accounts and records relating to the performance of the Contractor and to have them audited by auditors of the GOP or the Procuring Entity, as may be required.

#### 13. Advance Payment

The Procuring Entity shall, upon a written request of the Contractor which shall be submitted as a Contract document, make an advance payment to the Contractor in an amount not exceeding fifteen percent (15%) of the total contract price, to be made in lump sum, or at the most two installments according to a schedule specified in the **SCC**, subject to the requirements in Annex "E" of the 2016 revised IRR of RA No. 9184.

#### 14. Progress Payments

The Contractor may submit a request for payment for Work accomplished. Such requests for payment shall be verified and certified by the Procuring Entity's Representative/Project Engineer. Except as otherwise stipulated in the **SCC**, materials and equipment delivered on the site but not completely put in place shall not be included for payment.

#### 15. Operating and Maintenance Manuals

- 15.1. If required, the Contractor will provide "as built" Drawings and/or operating and maintenance manuals as specified in the **SCC**.
- 15.2. If the Contractor does not provide the Drawings and/or manuals by the dates stated above, or they do not receive the Procuring Entity's Representative's approval, the Procuring Entity's Representative may withhold the amount stated in the **SCC** from payments due to the Contractor.

## Section V. Special Conditions of Contract

#### **Notes on the Special Conditions of Contract**

Similar to the BDS, the clauses in this Section are intended to assist the Procuring Entity in providing contract-specific information in relation to corresponding clauses in the GCC found in Section IV.

The Special Conditions of Contract (SCC) complement the GCC, specifying contractual requirements linked to the special circumstances of the Procuring Entity, the Procuring Entity's country, the sector, and the Works procured. In preparing this Section, the following aspects should be checked:

- a. Information that complements provisions of the GCC must be incorporated.
- b. Amendments and/or supplements to provisions of the GCC as necessitated by the circumstances of the specific purchase, must also be incorporated.

However, no special condition which defeats or negates the general intent and purpose of the provisions of the GCC should be incorporated herein.

## **Special Conditions of Contract**

GCC Clause	
2	The contract duration is 70 calendar days inclusive of 15 days estimated unworkable days  Contractor's Working Hours  a. All normal work for this contract shall be performed during normal daylight hours. Any exceptions will require the written approval of the assigned officer/BGMS Project Engineer/Architect  b. If work is required overnight, the Contractor will be required to furnish safe, proper and sufficient lighting arrangement if necessary.  c. Works may be required on weekends/holidays and shall deploy a maximum number of manpower based on the submitted Contractor's Schedule to avoid interruptions of DSWD operations and service with proper coordination/approval to BGMS.
4.1	The Procuring Entity shall give possession of so much of the Site to the Contractor after a pre-construction meeting between the authorized DSWD Representatives and the Contractor.
6	Not Applicable
7.2	Fifteen (15) years
10	a. Dayworks are applicable at the rate shown in the Contractor's original Bid.
11.1	The Contractor shall submit the Program of Work to the Procuring Entity's Representative within <b>Ten</b> (10) Calendar Days of delivery of the Notice of Award.
11.2	The amount to be withheld for late submission of an updated Program of Work is <b>Ten Thousand Pesos</b> ( <i>PhP 10,000.00</i> )
13	The amount of the advance payment is up to <b>One Hundred Sixty Seven Thousand, Four Hundred Four Pesos and 60 Centavos (PhP 167,404.60)</b> (15% of the ABC only). The amount of Advance Payment may be granted upon request.
14	Not Applicable
15.1	The date by which "as built" drawings are required is within 15 Calendar Days upon completion of the contract.
15.2	The amount to be withheld for failing to produce "as built" drawings and/or operating and maintenance manuals by the date required is <b>PhP 20,000.00</b>

## Section VI. Specifications

#### **Notes on Specifications**

A set of precise and clear specifications is a prerequisite for Bidders to respond realistically and competitively to the requirements of the Procuring Entity without qualifying or conditioning their Bids. In the context of international competitive bidding, the specifications must be drafted to permit the widest possible competition and, at the same time, present a clear statement of the required standards of workmanship, materials, and performance of the goods and services to be procured. Only if this is done will the objectives of economy, efficiency, and fairness in procurement be realized, responsiveness of Bids be ensured, and the subsequent task of bid evaluation facilitated. The specifications should require that all goods and materials to be incorporated in the Works be new, unused, of the most recent or current models, and incorporate all recent improvements in design and materials unless provided otherwise in the Contract.

Samples of specifications from previous similar projects are useful in this respect. The use of metric units is mandatory. Most specifications are normally written specially by the Procuring Entity or its representative to suit the Works at hand. There is no standard set of Specifications for universal application in all sectors in all regions, but there are established principles and practices, which are reflected in these PBDs.

There are considerable advantages in standardizing General Specifications for repetitive Works in recognized public sectors, such as highways, ports, railways, urban housing, irrigation, and water supply, in the same country or region where similar conditions prevail. The General Specifications should cover all classes of workmanship, materials, and equipment commonly involved in construction, although not necessarily to be used in a particular Works Contract. Deletions or addenda should then adapt the General Specifications to the particular Works.

Care must be taken in drafting specifications to ensure that they are not restrictive. In the specification of standards for goods, materials, and workmanship, recognized international standards should be used as much as possible. Where other particular standards are used, whether national standards or other standards, the specifications should state that goods, materials, and workmanship that meet other authoritative standards, and which ensure substantially equal or higher quality than the standards mentioned, will also be acceptable. The following clause may be inserted in the SCC.

#### Sample Clause: Equivalency of Standards and Codes

Wherever reference is made in the Contract to specific standards and codes to be met by the goods and materials to be furnished, and work performed or tested, the provisions of the latest current edition or revision of the relevant standards and codes in effect shall apply, unless otherwise expressly stated in the Contract. Where such standards and codes are national, or relate to a particular country or region, other authoritative standards that ensure a substantially equal or higher quality than the standards and codes specified will be accepted

subject to the Procuring Entity's Representative's prior review and written consent. Differences between the standards specified and the proposed alternative standards shall be fully described in writing by the Contractor and submitted to the Procuring Entity's Representative at least twenty-eight (28) days prior to the date when the Contractor desires the Procuring Entity's Representative's consent. In the event the Procuring Entity's Representative determines that such proposed deviations do not ensure substantially equal or higher quality, the Contractor shall comply with the standards specified in the documents.

These notes are intended only as information for the Procuring Entity or the person drafting the Bidding Documents. They should not be included in the final Bidding Documents.

# <u>Please see attached Technical Specifications and General</u> <u>Conditions and Requirements</u>

## Section VII. Drawings

## See Attached Drawings/floor plans

## Section VIII. Bill of Quantities

#### **Notes on the Bill of Quantities**

#### **Objectives**

The objectives of the Bill of Quantities are:

- a. to provide sufficient information on the quantities of Works to be performed to enable Bids to be prepared efficiently and accurately; and
- b. when a Contract has been entered into, to provide a priced Bill of Quantities for use in the periodic valuation of Works executed.

In order to attain these objectives, Works should be itemized in the Bill of Quantities in sufficient detail to distinguish between the different classes of Works, or between Works of the same nature carried out in different locations or in other circumstances which may give rise to different considerations of cost. Consistent with these requirements, the layout and content of the Bill of Quantities should be as simple and brief as possible.

#### **Daywork Schedule**

A Daywork Schedule should be included only if the probability of unforeseen work, outside the items included in the Bill of Quantities, is high. To facilitate checking by the Entity of the realism of rates quoted by the Bidders, the Daywork Schedule should normally comprise the following:

- a. A list of the various classes of labor, materials, and Constructional Plant for which basic daywork rates or prices are to be inserted by the Bidder, together with a statement of the conditions under which the Contractor will be paid for work executed on a daywork basis.
- b. Nominal quantities for each item of Daywork, to be priced by each Bidder at Daywork rates as Bid. The rate to be entered by the Bidder against each basic Daywork item should include the Contractor's profit, overheads, supervision, and other charges.

#### **Provisional Sums**

A general provision for physical contingencies (quantity overruns) may be made by including a provisional sum in the Summary Bill of Quantities. Similarly, a contingency allowance for possible price increases should be provided as a provisional sum in the Summary Bill of Quantities. The inclusion of such provisional sums often facilitates budgetary approval by avoiding the need to request periodic supplementary approvals as the future need arises. Where such provisional sums or contingency allowances are used, the SCC should state the manner in which they will be used, and under whose authority (usually the Procuring Entity's Representative's).

The estimated cost of specialized work to be carried out, or of special goods to be supplied, by other contractors should be indicated in the relevant part of the Bill of Quantities as a particular provisional sum with an appropriate brief description. A separate procurement procedure is normally carried out by the Procuring Entity to select such specialized contractors. To provide an element of competition among the Bidders in respect of any facilities, amenities, attendance, etc., to be provided by the successful Bidder as prime Contractor for the use and convenience of the specialist contractors, each related provisional sum should be followed by an item in the Bill of Quantities inviting the Bidder to quote a sum for such amenities, facilities, attendance, etc.

#### **Signature Box**

A signature box shall be added at the bottom of each page of the Bill of Quantities where the authorized representative of the Bidder shall affix his signature. Failure of the authorized representative to sign each and every page of the Bill of Quantities shall be a cause for rejection of his bid.

These Notes for Preparing a Bill of Quantities are intended only as information for the Procuring Entity or the person drafting the Bidding Documents. They should not be included in the final documents.

REPUBLIC OF THE PHILIPPINES				
CORDILLERA ADMINISTRATIVE REGION				
	Contract F	Referenc	e Number: ITB-2	025-DSWD-CAR- 05
Name of Project:	Renovation	on of Sar	nitary Systems of D	SWD FO-CAR
	Training C	enter C	ompound	
Standard Form Number SF-INFR-55	Location o	of the Pr	oject: Engineer's F	lill, Baguio City
Revised on: August 11, 2004				

## BILL OF QUANTITIES

	•				
				Columns 5 & 6 a	re to be filled by
	Columns 1, 2, 3 & 4 are to be filled up by the Procuri			the bidders	
ITEM				UNIT PRICE	AMOUNT
NO.	ITEM DESCRIPTION	Unit	QTY	(PESOS)	(PESOS)
	2	3	4	5	6
1	GENERAL REQUIREMENTS			3	-
	Mobilization/Demobilization	lot	1.00		
	Project Billboard	each	2.00		
	Clearing, Cleaning and Hauling	lot	1.00		
2	Civil Works/Site Works	100	1.00		
	Removal of Existing Septic Tank, Removal of Existing				
	Water Lines, Sewer Lines and Plumbing Fixtures at				
2.1	3rd Floor, Demolition of Masonry Walls and Tiles at	lot	1.00		
	3rd Floor Comfort Room				
2.2	Excavation	CI I PO	33.93		
		cu.m			
	Masonry Works	sq.m	9.26		
	Washing Area	lot	1.00		
3	ARCHITECTURAL WORKS		20.27		
	Ceiling Works	sq.m	20.27		
	Tile Works	sq.m	57.10		
	Doors	set	8.00		
	Dry Wall Partition	sq.m	29.20		
	Painting Works	lot	1.00		
4	ELECTRICAL WORKS				
4.1	Conduits, Boxes & Fittings (Conduit Works/Conduit	lot	1.00		
	Rough-in)		2.00		
	Wires and Wiring Devices	lot	1.00		
	Lighting, Fixtures and Other Accessories	lot	1.00		
	SANITARY/PLUMBING WORKS				
5.1	Centralized Septic Tank	lot	1.00		
5.2	Water Line	lot	1.00		
5.3	Sewer Line/Vent Pipe	lot	1.00		
	Plumbing Fixtures				
	> Water Closet w/ fittings and accessories (5 sets)				
	> Urinal w/ complete accessories (3 sets) > Lavatory (4 sets)				
	> Floor drain (3 pcs)				
5.4	> Tissue holder (5 pcs)	lot	1.00		
	> Lavatory Faucet (4 pcs)				
	> Bidet (5 pcs)				
	> Stainless Steel Grab bar, 40mm diam (1 pc)				
	> Facial Mirror (36.58 ft.)				
6	Others				
6.1	Repair and Restoration of all affected	lot	1.00		
	structure/materials during construction				
7	Construction Safety and Health				
	Safety Shoes	pairs	5.00		
	Hard Hat 30	pcs	5.00		
7.3	Reflective Vest	pcs	5.00		
7.4	Safety Signages	lot	1.00		
TOTA	L BID PRICE:				
TOTA	L AMT. IN WORDS: (in words)		_		

# Section IX. Checklist of Technical and Financial Documents

#### **Notes on the Checklist of Technical and Financial Documents**

The prescribed documents in the checklist are mandatory to be submitted in the Bid, but shall be subject to the following:

- a. GPPB Resolution No. 09-2020 on the efficient procurement measures during a State of Calamity or other similar issuances that shall allow the use of alternate documents in lieu of the mandated requirements; or
- b. any subsequent GPPB issuances adjusting the documentary requirements after the effectivity of the adoption of the PBDs.

The BAC shall be checking the submitted documents of each Bidder against this checklist to ascertain if they are all present, using a non-discretionary "pass/fail" criterion pursuant to Section 30 of the 2016 revised IRR of RA No. 9184.


## **Checklist of Technical and Financial Documents**

#### I. TECHNICAL COMPONENT ENVELOPE

#### Class "A" Documents

<u>Legal Documents</u>			
	Valid PhilGEPS Registration Certificate (Platinum Membership) (all pages) in accordance with Section 8.5.2 of the IRR;		
(b) St	<u>Documents</u> tatement of the prospective bidder of all its ongoing government and private ontracts, including contracts awarded but not yet started, if any, whether similar not similar in nature and complexity to the contract to be bid; <u>and</u>		
(c)	Statement of the bidder's Single Largest Completed Contract (SLCC) similar to the contract to be bid, except under conditions provided under the rules; <a href="mailto:and">and</a>		
(d)	Special PCAB License in case of Joint Ventures $\underline{and}$ registration for the type and cost of the contract to be bid; $\underline{and}$		
(e)	Original copy of Bid Security. If in the form of a Surety Bond, submit also a certification issued by the Insurance Commission <u>or</u> original copy of Notarized Bid Securing Declaration; <u>and</u>		
(f)	<ul> <li>Project Requirements, which shall include the following:</li> <li>a. Organizational chart for the contract to be bid;</li> <li>b. List of contractor's key personnel (e.g., Project Manager, Project Engineers, Materials Engineers, and Foremen), to be assigned to the contract to be bid, with their complete qualification and experience data;</li> </ul>		
	c. List of contractor's major equipment units, which are owned, leased, and/or under purchase agreements, supported by proof of ownership or certification of availability of equipment from the equipment lessor/vendor for the duration of the project, as the case may be; and		
(g)	Original duly signed Omnibus Sworn Statement (OSS) <u>and</u> if applicable, Original Notarized Secretary's Certificate in case of a corporation, partnership, or cooperative; or Original Special Power of Attorney of all members of the joint venture giving full power and authority to its officer to sign the OSS and do acts to represent the Bidder.		
Financial (h)	<u>Documents</u> The prospective bidder's computation of Net Financial Contracting Capacity (NFCC).		

	Class "B" Documents						
(i)	If applicable, duly signed joint venture agreement (JVA) in accordance with						
	RA No. 4566 and its IRR in case the joint venture is already in existence or						
	duly notarized statements from all the potential joint venture partners stating						
	that they will enter into and abide by the provisions of the JVA in the instance						
	that the bid is successful.						
II EINANCI	AL COMPONENT ENVELOPE						
	Original of duly signed and accomplished Financial Bid Form; and						
Other doc	cumentary requirements under RA No. 9184						
(k)	Original of duly signed Bid Prices in the Bill of Quantities; and						
	Duly accomplished Detailed Estimates Form, including a summary shee						
	indicating the unit prices of construction materials, labor rates, and equipmen						
	rentals used in coming up with the Bid; and						
(m)	Cash Flow by Quarter.						
(111)	Cush 1 low by Quartor.						



#### GENERAL CONDITION AND REQUIREMENTS 1. Contractor's Qualification(s) a. Contractor shall be competent and meaningful experienced in the field of Construction/Repair/Renovation/Improvement Works with a minimum of two (2) year prior experience. 2. Contractor's Working Hours a. All normal work for this contract shall be performed during normal daylight hours. Any exceptions will require the written approval of the assigned Officer/BGMS Project Engineer/Architect. b. If work is required overnight, the Contractor will be requires to furnish safe, proper and sufficient lighting arrangement if necessary. c. Works may be required on weekends/holidays and shall deploy a maximum number of manpower based on the submitted Contractors Schedule to avoid interruptions of DSWD operations and service with proper coordination/ approval to BGMS. 3. Contractor's Responsibilities a. Contractor/Service provider shall request a Pre-Construction Meeting with BGMS Team before the start of work; b. Contractor/Service provider shall coordinate to the BGMS all the execution of works; c. Contractor/Service provider shall submit Statement of works accomplished and progress photos as requirement of the billing request; d. Contractor shall submit Construction Safety and Health Program approved by DOLE; e. Contractor shall submit own construction schedule within ten (10) working days after the receipt of Purchase Order f. Contractor/ Service provider shall provide warning signages on on-going works; g. Contractor/Service provider shall provide complete uniform with ID and basic PPE for all the construction worker and personnel; h. Any damages done during working hours shall be paid by the Contractor's own expense. 4 Other Requirements a. All dimensions/level etc. indicated in the drawing plans are to be verified on the site; b. All materials is subjected for the approval of the End user/ BGMS Project Engineer/Architect: c. Removal, dismantling and demolition work shall be coordinated and requested to the BGMS Team: d. Any discrepancies, either between written dimensions and site dimensions shall be brought to the BGMS office before executing the works. e. The Contractor/ Service Provider shall ensure quality of work and warranty of at least one (1) year from the completion of project.

Prepared by:

Recommending Approval:

ENGRESIEMARIO A. REAMICO

Engineer II, BGMS

RINA CLAIRE L. REYES

Concurrent AD Chief and OIC ARD for Administration

Conformed by

YXTERN RUDIO

MARIA C. APLATEN

Regional Director

Approved



# **GENERAL SPECIFICATIONS**

# "RENOVATION OF SANITARY SYSTEM OF DSWD FO CAR TRAINING CENTER"

Engineer's Hill, Baguio City

WRITTEN AND PREPARED BY:

ENOT. RICHARD A. REAMICO

Engineer II, BGMS



r, č

#### **GENERAL CONDITIONS**

# GC - 1. DEFINITIONS

- The term "Owner" as used in these Specifications means the administration of the Department of Social Welfare and Development – Cordillera Administrative Region. (DSWD-CAR)
- ii. The term "Construction Architect/Engineer" shall mean the person executing the contract on behalf of the Owner for the construction of the project and the said Construction Architect/Engineer's duly authorized assistants or representatives.
- iii. The term "Contractor" means the entity that will provide all labor, materials, equipment, and perform all the work necessary for the completion of the project in accordance with the plans and specifications.
- iv. The term "Consultants" means the designer and planner of the owner.
- v. The term "Completion of Contract" shall mean full performance by the contractor of the contractor's obligations under the contract and all amendments and revisions thereof except the contractor's obligation concerning (1) release of liens and certificate of contractor, (2) other final documents. The term "completion" or "completion of the project" shall mean the contract and all amendments and revision thereof. The Certificate of Completion, signed by the Construction Architect/ Engineer and approved in writing by the Owner shall be the sole and conclusive evidence as to the date of completion.
- vi. The term "default" used herein shall include any such failure by the contractor to make progress in the prosecution of work so as to endanger the completion of the project within the calendar days allotted.
- vii. Wherever in the specifications or upon the drawings the words "directed", "required", "ordered", "designated", "prescribed", or words of like import are used, it shall be understood that the direction, requirement, designation, or prescription, of the Construction Architect/Engineer is intended; and similarly, the words "approved", "acceptable to", or satisfactory to" of the Designer unless otherwise expressly stated.
- viii. Where "as shown", "as indicated", "as detailed", or words of similar import are used, it shall be understood that the reference is made to the drawings accompanying this contract unless stated otherwise. The word "provided", as used herein shall be understood to mean "provided complete in place", that is, furnished and installed.

# GC - 2. DIVISION OF THE SPECIFICATION

These specifications are divided for convenience into sections as set forth in the Table of Contents preceding the General Conditions. Any mention in these sections or indications on the drawings of articles, materials, operations, or methods, requires that the contactor furnish each item so mentioned or indicated, of the kind, type or design and quality specified or shown on the drawings, and that the contractor furnish all labor, equipment, incidentals, and superintendence necessary to complete the work in accordance with the true meaning and intent of these specifications even though such mention of articles, materials, operations, methods, quality, qualifications, or condition is not expressed in complete sentences. The



contractor shall coordinate the work covered in each section with the work of other sections. The necessary information – items, accessories, anchors, connections, patterns, templates etc. – shall be delivered when required in order to prevent any delay in the progress and completion of work.

# GC - 3. SPECIFICATIONS AND DRAWINGS

- i. The contractor shall keep in the work place a copy of the drawings and specifications and shall at all times give the Construction Architect/Engineer access thereto. Anything mentioned in the specifications and not shown on the drawings, or shown on the drawings and not mentioned in the specifications, shall be like effect as if shown or mentioned in both. In case of difference between drawings and specifications the specifications shall govern. In case of discrepancy either in the figures, in the drawings, or specifications, the matter shall be promptly submitted to the Designing Architect who shall promptly make a determination in writing. Any adjustment by the contractor without such determination shall be at his risk and expense. The Consultants shall furnish from time to time such detailed drawings and other information as he may consider necessary, unless otherwise provided.
- ii. Omissions and misdescription. Omissions from the drawings or specifications or misdescription of details of work which are manifestly necessary to carry out the intent of the drawings and specifications, or which are customarily performed, shall not relieve the contractor from performing such omitted or misdescribed details of work, but shall be performed as if fully and correctly set forth and described in the drawings and specifications.
- iii. Deviations from the drawings and dimensions therein given, whether or not error is believed to exist, shall be made only after written authority is obtained from the Designing Architect/Engineer.

# GC - 4. PROGRESS SCHEDULE

The work shall be prosecuted with faithfulness and energy and in the order of precedence as directed by the Construction Architect/Engineer. The Contractor shall submit a progress schedule as follows:

- The progress schedule shall be submitted within two weeks after the date of award of contract and shall be subjected to the approval of and/or modification by the Construction Architect/Engineer.
- ii. The progress schedule shall be in Chart Form or Critical Path Method (CPM) and shall show the order in which the contractor proposes to carry on the work, the dates on which he will start the several salient features (including procurement of materials, plant and equipment) and the contemplated dates completing the same.

# GC - 5. TAXES, LICENSES, PERMITS, AND FEES

All taxes, licenses, permits and fees which may be due to the local and/or National Government on account of the performance and completion of the work stipulated herein and fees for testing materials and specimens shall be paid for and obtained by the contractor while the building and occupancy permits shall be paid for by the contractor and Owner respectively.



#### GC - 6. INSURANCE

The contractor shall take out and maintain throughout the construction period insurance with the minimum requirements.

# GC - 7. CHANGES IN SPECIFICATIONS AND DRAWINGS

The owner may, from time to time, during the progress of the construction of the project, make such changes in, additions to, or subtractions from the specifications and construction drawings as condition may warrant: provided, however, that if the cost to the contractor shall be materially increased by any such change, or addition, the owner shall pay the contractor for the reasonable cost thereof in accordance with a construction contract amendment signed by the owner and the contractor, but no claim for additional compensation for any such change or addition will be considered unless the contractor shall have made a written request therefore to the owner prior to the commencement of work in connection with such change or addition. Written notification shall be made by the owner to the consultants or designing architect prior to any change in specifications and drawings.

# GC - 8. SUPERVISION AND INSPECTION

- i. The contractor shall cause the construction work on the project to receive a constant supervision by a competent Project Architect/Engineer who shall be present at all times during the working hours where construction is being carried-on. The contractor shall employ, in connection with the construction of the project, capable, experienced, and reliable foremen and such skilled workmen as may be required for the various scope of work to be performed. Directions and instructions given to the Project Architect/Engineer by the owner shall be binding upon the contractor.
- ii. The manner of performance of the work, and all equipment used therein shall be subject to the inspection, tests, and approval of the owner. The owner shall have the right to inspect data and records of the contractor relevant to the work. The contractor will provide all reasonable facilities necessary for such inspection and tests. The contractor shall have an authorized agent to accompany the inspector when the final inspection is made and, if requested by the owner, when any other inspection is made.

#### GC - 9. PROGRESS PHOTOGRAPHS

- i. The contractor, at his expense, shall furnish to the Construction Architect/Engineer progress photographs that shall be taken monthly starting when the work begins and continuing so long as the work is in progress, on the exterior or interior of the building, from the station points designated by the Construction Architect/Engineer.
- ii. The contractor shall clearly identify in the photographs the scope of work completed.
- iii. No partial payment shall be considered for approval without the above-mentioned photographs.

# GC - 10. RELEASE OF LIENS

Neither the final payment nor any part of the retained percentage shall become due until the contractor, if required shall deliver to the owner a complete release of all liens arising out of the contract, or receipts in full in lieu thereof and, if required in either case, an affidavit



that so far as he has knowledge or information, the releases and receipts include all labor and materials for which a lien can be filed.

# GC - 11. SUPERVISION

All work shall meet with the approval of the Construction Architect/Engineer and shall be completed in conformity with the plans and specifications approved by, and on file with the owner, which plans and specifications will be made part of the contract to be entered into for the work referred herein. The contractor shall confer with the Construction Architect/Engineer before commencing any work under the contract. The contractor shall furnish all facilities for inspection at the construction site.

# GC - 12. IDENTIFICATION OF EMPLOYEES

The contractor shall be responsible for furnishing to each employee and for requiring each employee engaged in the work to display such identification as maybe approved and directed by the Construction Architect/Engineer.

# GC - 13. SAMPLES

The contractor shall submit 2 each of samples if required by the owner or Construction Architect/Engineer and these shall be properly identified with the contractor's name and manufacturer's name and catalog number, if applicable.

# GC - 14. LIGHT, POWER, AND WATER

The contractor shall furnish temporary water, light, and power, complete with connecting piping, wiring, lamps and similar equipment as required for the work. The contractor shall install, maintain, and remove his temporary line upon completion of the work. All expenses in connection with temporary services and facilities shall be paid by the contractor.

#### GC - 15. TEMPORARY OFFICE

The contractor shall provide and maintain watertight office on the premises where directed for his own and sub-contractor's use and for the use of the Construction Architect/Engineer. This office shall be, provided with operating windows, doors with locks, tables, benches, racks for drawings and adequate electric lighting.

- i. The ceiling shall be 2.7m high. Floor and wall shall be plywood or equivalent.
- ii. The contractor shall provide janitorial services for these offices for the duration of the job.

# GC - 16. STORAGE SHEDS

The contractor shall provide and maintain on the premises where directed, watertight storage sheds for all materials which might be damaged by weather.

# GC - 17. TEMPORARY TOILETS

The contractor shall install and maintain in a sanitary condition suitable toilets and urinals for use of workmen. These toilets shall be in a location approved by the construction Architect/Engineer and connected to existing sewers, when feasible. There shall be a minimum of one (1) toilet for each multiple of thirty (30) contractor's employees or fractional part thereof, working at the job site.

# GC - 18. LIGHTS, GUARDS, ETC.

The contractor shall provide such lights, guard, temporary fences, and warning signs as may be necessary for the safety during all the time from the execution of the contract until



the final acceptance of the work, and shall be responsible for the installation and maintenance of lights, guards, fences and warning signs.

#### GC - 19. CLEANING

Upon the completion of each part of the work as defined by the sections into which these specifications are divided or as separated by the various trades involved in the work, each area shall be cleaned of debris emanating from the work. The contractor shall remove remaining excess materials, waste, rubbish, debris, and his construction and installation equipment from the premises. Any dirt or stains caused by the work under the contract shall be removed from the surfaces of the structure and from the equipment and fixtures.

#### MISCELLANEOUS CONDITIONS

#### MP - 1. PROJECT SIGN

The contractor shall provide a project sign fabricated to size.

# MP - 2. USE OF OWNER FACILITIES BY CONTRACTOR

The contractor will not be permitted to utilize any Owner's building or facility for his jobsite office space or storage area for materials without prior written approval of the Construction Architect/Engineer.

#### MP - 3. INTERFERENCE WITH OWNER OPERATIONS

The contractor shall establish work procedures and methods to avoid interference with existing operations within or adjacent to the construction area. Free passage into the adjoining or adjacent buildings not in the contract will not be permitted, except as approved by the Construction Engineer. Procedures and methods shall also provide for safe conduct of work and protection of property, which is to remain undisturbed.

# ARCHITECTURAL

#### SECTION 1 CONSTRUCTION QUALITY CONTROL

1C.1. <u>General</u>. The contractor shall establish and maintain quality control for testing of materials to be

furnished by him in accordance with the specifications and fro determination of densities as required in

the specifications to assure compliance as specified. The testing agency shall be approved. Certified

copies of detailed laboratory test reports, attesting compliance with the test requirements as prescribed

in the applicable referenced publications shall be submitted in triplicate, together with the submission of

samples for conformation testing by the owner as required, and shall contain the name and address of

the testing laboratory and the dates of the test to which the report applies.

1C.2. <u>Sampling and Testing</u>. Unless otherwise specified, materials to be sampled, time of submittal of



samples, and other requirements for sampling shall be as specified in the various sections of each

division under which the materials will be furnished. All samples for testing shall be provided by the

contractor at no additional cost to the owner.

1C.3. <u>Maintenance of records</u>. The contractor will maintain current records of all inspections and test

performed on an appropriate format. These records will provide factual evidence that required inspections

or tests have been performed, including type and number of inspections or tests involved; results of the

inspections or tests, etc. Additional forms for specific operations may be required by the Construction

engineer to supplement the daily inspection forms.

1C.4. <u>Time reports and deficiencies</u>. Records of jobsite material inspections must be received prior to

installation or incorporation of materials into the contract work. The contractor will not be permitted to

build upon or conceal any features of the work containing uncorrected defects. Payment on deficient

items will be withheld until satisfactorily corrected or other action has been taken approved.

# **SECTION 2 EARTHWORK**

#### General

Include cut and fill, compaction and grading to acquire finished grade as required in the plan.

# 2.1 EXCAVATION

Structural excavation, to indicate bearing value. Extra care should be practiced to protect adjoining properties and existing utility lines. Excavation of trenches for pipe lines shall conform to the typical sections as Shown on the plans.

#### 2.2 SITE CLEARING

- 2.2.1 All obstacles within the premises shall be disposed and cleared as directed by the Project Architect/Engineer.
- 2.2.2 All obstruction obstructing the work shall be removed to the designated places, unless otherwise directed by the Project Architect/Engineer.
  - 2.2.3 All plant roots shall be disposed.

# 2.3 BACKFILL & FILL

- 2.3.1 Backfill of suitable excavated soil shall be placed in horizontal layers of 30 cm thick, compacted by hand or mechanically as required density.
- 2.3.2 Fill shall be as shown in the drawings unless otherwise directed and shall be compacted by mechanical means to require density of 95% optimum.



2.3.3 Excess earth-surplus earth from cut portion shall be placed in lower ground as desired by the Project Engineer to the nearest depressed area.

# SECTION 3 DEMOLITION, CLEARING AND GRUBBING

#### 3.1 EXAMINATION OF SITE

The Contractor shall visit the site of the work and examine the premises so as to fully understand all of the existing conditions relative to the work. No increase in cost of extension in performance time will be considered for the failure to know its condition.

#### 3.2 DEMOLITION

Demolition of work in general shall consist of the following:

- 3.2.1 Remove all existing structures (if there shall be)
- 3.2.2 Tap all existing water and electrical lines for reconnection to new construction.

# 3.3 PROTECTION OF STRUCTURES AND PROPERTY

- 3.3.1 Execute demolition work with such manner as to insure adjacent property and premises of building against damage which occur or might occur from falling debris or other cause.
- 3.3.2 Repair damage done to property of any person or persons on or off premises by reason of required work.
- 3.3.3 Provision of proper enclosure within the perimeter to insure safety to possible damage on adjacent properties.
- 3.3.4 Storage of any hazardous or flammable materials is strictly prohibited, that would cause danger to people, property and adjacent property.

#### 3.4 DISPOSAL OF MATERIALS

Observe good housekeeping, all trash, rubbish, and other waste shall be immediately disposed. The contractor should provide garbage cans for proper disposal of his wastes.

# 3.5 DEBRIS

- 3.5.1 Remove as it accumulates, debris resulting from demolition operation may not be burned on site.
- 3.5.2 Wood and other debris resulting from demolition operation may not be burned on site.

# 3.6 CLEANING

- 3.6.1 Upon the completion of work, remove all barricades, tools, materials, apparatus and debris.
  - 3.6.2 Leave premises clean, neat and orderly.

# SECTION 4 FOUNDATION AND EXCAVATION WORKS

4.1 Gravel Bed -4" thick compacted on bottom of foundation and or footing trenches or provide lean concrete.



- 4.2 Minimum depth of Excavation From natural grade line.
- 4.3 All excavation work for foundation based on drawing shall be from natural grade, no foundation shall rest on fill.

# SECTION 5 FILLING, GRADING AND SLABS ON FILLS

5.1 1-part escombro, 2-part lastillas or Barrow earth for filling job, done 6 layers, compacted.

Filling shall be confined on building areas.

- 5.2 Second Basement and side walk slabs on fill -0.15 m thick, reinforced with 12 mm diameter bars spaced at 0.35m on center both ways, 3,000 psi.
- 5.3 2" thick gravel bedding is used for slabs on fill. Do not use unsuitable organic filling materials.

# SECTION 6 CONCRETE AND REINFORCED CONCRETE

- 6.1 Test Steel bars, cement, gravel, sand and concrete samples, shall be tested. Sample materials for testing shall be properly signed by the Project Engineer with corresponding date before issuing to private testing company. Results shall be officially signed or stamp and to be photo copied for four. The Owner shall be furnished a copy of every testing results.
- 6.2 Schedule of Concrete
  - 6.2.1 Footing, tie beams, reinforced walls, wall footings, columns, and pedestal; f'c = 24.00 MPa (3500 psi) at 28 days
  - 6.2.2 Suspended slabs, beams, girders, stairs;
  - f'c = 24.00 MPa (3500 psi) at 28 days
  - 6.2.3 Ground Floor slab on fill:
  - f'c = 20.70 MPa (3,000 psi) at 28 days
  - 6.2.4 Others not specified f'c = 20.70 MPa (3,000 psi) at 28 days
  - 6.2.5 Cement approved brand. Portland cement
  - 6.2.6 Gravel G-1 crushed, 1/2" to 3/4" in size
  - 6.2.7 Sand shall be river sand
  - 6.2.8 Reinforcing Bars:
  - 1. All mild reinforced bars shall be round deformed structural grade in accordance with ASTM A-615.


16mm & larger rebars - fy = 275.79 MPa (40, 000 psi)

12mm & smaller - fy = 275.79 MPa (40, 000 psi)

- 2. Verify Structural general notes. For specific grade of bars for specific use.
- 6.2.9 Forms Use plywood or steel forms for all form works.

#### SECTION 7 MASONRY WORKS

- 7.1 Concrete Hollow Blocks 5" thick for exterior wall, 3" or 4" thick for all interior partitions unless otherwise noted. Both 1" thick cement plastered. With compressive strength of 700 psi.
- 7.2 Reinforcement 12mm dia. Bars at 0.40 m on center for vertical and every 3 layers of CHB for horizontal bars on all concrete hollow blocks wall.
- 7.3 Cement and other cement materials shall be delivered to the site and stored in



unbroken bags, barrels, or other approved containers, plainly marked and labeled with the manufacturers name and brand. Concrete masonry units shall be handled with care to avoid chipping and breakage, and shall be stored as directed.

#### SECTION 8 STRUCTURAL STEEL WORKS

- 8.1 General. Connections for which details are not indicated shall be designed in accordance with the Steel Construction standard.
- 8.2 Handling, shipping and storing steel work. All Materials shall be handled, shipped, and stored in a manner that will prevent distortion or other damage. Materials shall be stored in a clean location and keep properly drained. All damaged materials shall be replaced or repaired by and the expense of the contractor.
- 8.3 Structural carbon steel for welded work shall conform to ASTM A36.
- 8.4 Submerged arc welding. Bare electrodes and flux for submerged arc welding shall conform to the requirements of AWS D1.0, and the grade of A36.

#### **SECTION 9 DOORS AND WINDOWS**

DOOR - See Architectural Plans for specifications.

WINDOW - See Architectural Plans for specifications.

## SECTION 10 FLOOR FINISH SCHEDULE

See Architectural Plans for specifications.

#### SECTION 11 CEILING FINISH SCHEDULE

See Architectural Plans for specifications.

# **SECTION 12 PAINTING WORKS**

- 12.1. Materials Any Quality Paint or approved Equal.
- 12.2. Application All applications and methods to be used shall follow strictly manufacturer's instructions and specifications.
- 12.3. SURFACE TREATMENT All surface include masonry wall shall be thoroughly cleaned, puttied (masilla), sand papered rub and polish. All Masonry wall shall be treated first with penetrating sealer prior to painting.
- 12.4. SCHEDULE OF PAINTING FINISHES:
  - 1. All masonry wall cemented finished surfaced 3 coats Flat Top Coat.
  - 2. Plywood surfaces or wood surfaces 1 coat primer and 2 coats Semi-gloss Top Coat.
  - 3. Hardiflex 1 coat primer, 2 coats Flat Top Coat. Color White.
  - 4. Steel and metal works. 2 coats red oxide primer and 2 coats acqua epoxy or quick drying enamel.
- Steel Trusses 2 coats red oxide primer and two coats acqua epoxy topcoat.
   Extra Coats shall be applied to achieve desired finish.

# PLUMBING WORKS SECTION 1 GENERAL

- 1.1 DESCRIPTION
  - 1.1.1 Applicable provisions of "General Conditions" govern work under this section.



- 1.1.2 All fittings, connections and piping embedded in concrete shall be subjected to inspection by the Construction Architect/Engineer and/or his representative before completion.
- 1.1.3 The Contractor shall provide all items, articles, materials, operation or method listed, mentioned of schedule of the drawings and/or herein, including labor. Materials, equipment's and incidentals necessary and required for their completion.
- 1.1.4 It is not intended that the drawings shall show every pipe, fitting, valve and appliance. All such items whether specifically mentioned or not, or indicated on the drawing shall be furnished and installed, if necessary, to complete the system in accordance with the best practice of plumbing trade and to the satisfaction of the construction engineer and the owner.
- 1.1.5 The plumbing contractor is required to refer to all architectural, structural, mechanical and electrical plans and specifications and shall investigate all possible interferences and conditions affecting his work.
- 1.1.6 Electrical system is not included in this division, but the plumbing contractor will provide all facilities and make provisions for the installation of the work as construction progresses.

#### 1.2 SCOPE OF WORK

Work include under this section of the specifications consists in furnishing all labor, tools and equipment, appliances and materials necessary for complete installation, testing and operation of the plumbing system in accordance with the contract.

- 1.2.1 Sanitary drains from the building and their connections to the point of discharge as shown in the plans as verified at the jobsite.
- 1.2.2 Roof and ground storm drainage system and connections to the storm drainage system as shown in the plans as verified at the jobsite.
- 1.2.3 Soil, waste and vent pipe system within the building.
- 1.2.4 Cold water distribution and supply pipes to the fixtures.
- 1.2.5 Plumbing fixtures, trims and accessories.
- 1.2.6 Supply and installation of the standpipe system complete with the valves and fire department connection.
- 1.2.7 Water meter and water connections to cold water main and/or other sources as shown in the plan schemes.
- 1.2.8 The contractor shall provide necessary shop drawing as-built plans.
- 1.2.9 All other works described in other sections of this document necessary for the completion of this contract.

#### 1.3 SUBMITTALS

- 1.3.1 Within fifteen (15) days after award of contract, the plumbing contractor shall submit for the construction engineer's approval four (4) copies of all complete list of manufacturer's name of all materials he proposes to use.
- 1.3.2 After approval of the above list and before purchase of any equipment or materials. The plumbing contractor shall submit to the construction engineer for approval four (4) complete sets of detailed information consisting of



manufacturer's bulletins, shop drawings and part list of the materials to be provided under this contract.

1.3.3 The plumbing contractor shall assume the cost of entire responsibility of any change in the work as shown in the contract drawings which may necessary be occasioned by approval of materials other than these specified.

# 1.4 APPLICABLE CODE AND STANDARDS

- 1.4.1 All plumbing works to be done and sizes of pipes to be used shall be in accordance with the National Plumbing Code of the Philippines.
- 1.4.2 The plumbing contractor shall specify the above paragraphs with each section of the specifications and coordinate his work so that the General Contractor will understand clearly the intent of the work to be done.

#### **SECTION 2 PRODUCTS**

# 2.1 DESCRIPTION

All materials to be used shall conform to the standards specified. All classes listed are not necessarily required for this project, of classes listed; only those specifically called for under sections of this Division or shown shall be provided. Use of materials shall further be governed by other requirements imposed on other sections of this specification. Materials shall be subjected to test necessary to ascertain their fitness if the Construction Architect/engineer so requires.

#### 2.2 ALTERNATIVE MATERIALS

Use of any materials not specified in these specifications may be allowed, provided such alternate has been approved by the Construction Engineer, and provided further that a test, if required, shall be done by an approved agency in accordance with the generally accepted standards.

# 2.3 IDENTIFICATION OF MATERIALS

- 2.3.1 Each length of pipe, fittings, traps, fixtures and devices used in plumbing system have cast, stamped or indelibly marked on it in the manufacturer's trademark or name, the weight, type and classes of products when so required by the standards mentioned.
- 2.3.2 All materials and equipment mentioned in this specification, including all incidental items not specifically indicated but required to complete the contract shall be new and free from defects. If damaged during the course of construction, it shall be repaired or replaced as directed by the construction engineer at no additional cost to the owner.

## 2.4 STANDARD SPECIFICATION FOR MATERIALS AND EQUIPMENT

#### 2.4.1 WATER LINE PIPES

All cold water lines inside the building shall be any brand but quality pipe for the purpose.

# 2.4.2 POLYVINYL CHLORIDE PIPE

- 1. Solvent Cement joint to ASTM D2564.
- 2. Series 1000 for downspouts, main vents and soil stacks including horizontal drain.
- Series 600 for vent pipes and fittings.



#### SECTION 3 EXECUTION

#### 3.1 PIPING INSTALLATION

#### 3.1.1 General

- 1. Piping shall be installed as shown on the drawings, as recommended by the manufacturer and as directed during installation, straight and direct as possible, forming right angles or parallel lines with building walls, and other pipes, and neatly spaced. Erect pipe risers plumb and true, parallel with walls and other pipes neatly spaced.
- 2. All piping shall be properly supported or supported on stands, clamps, hangers or equivalent of approved design.
- 3. The arrangement positions and connections of pipes, fixtures, drains, valves and the like, indicated on the drawings shall be followed as closely as possible. The right is reserved by the construction engineer to change locations and elevations to accommodate conditions which may arise during the progress of the work, prior to installations, without additional compensation for such changes.
- 4. The responsibility for accurately laying out of the work and coordination of installation with other contracts rests with this contractor. Any field layout interferences that occur shall be reported immediately to the construction engineer.
- 5. All pipes shall be cut accurately to measurements and shall be worked into places without springing or forcing. Changes in pipe sizes shall be made with reducing fittings.
- 6. Roughing-in for pipes and fixtures shall be carried along the building construction. Correctly located openings of proper sizes shall be provided where required in the walls and floors for the passage of pipes. All items to be embedded in concrete shall be thoroughly cleaned and free from all rust, scale and paint.
- 7. Pipes shall not pass through columns, footings, beams or ribs, except where noted in the drawings.

# ELECTRICAL WORKS SECTION 1 GENERAL REQUIREMENT

#### 1.1 GENERAL

#### 1.1.1 General Description

1. The work to be done under this division of the specifications consist of the fabrication, finishing, delivery and installation, complete in all details of the Electric Work at the premises and all work materials incidental to the proper completion of the installation, except those portions of the work which are expressly stated to be done by others. All works shall be done in accordance with the governing Codes and Regulations and with the specifications. The specifications are intended to provide a broad outline of the required



equipment, but are not intended to include all details of design and construction.

2. Under this Section of the Specifications, provide all labor, materials and equipment and performance of all work necessary for the complete execution of all the electrical works as shown in the electrical drawings except specifically indicated as to be provided by the other.

# 1.1.2 Codes, Inspections, Permits and Fees

- 1. The work under this contract is to be installed according to the requirements of the latest edition of the Philippine Electrical Code, the rules and regulations of the local authorities and the requirements of the local power utility and Telephone Company.
- 2. All permits and electrical fees required for this work shall be obtained by and at the expense of the contractor. The contractor shall furnish the Construction Engineer and the Owner final certificates electrical inspection and approval from the proper government authorities after completion of work. The Contractor shall prepare all as-built and all forms and documents required by the approving authority.

# 1.1.3 Guarantees

The contractor shall guarantee that the electrical systems are free from all grounds and from all defective workmanship and materials and will remain so for a period of one year from date of acceptance of work. Any defects, appearing within aforesaid period, shall be remedied by the contractor at his own expense.

# SECTION 2 INTERIOR WIRING SYSTEMS

#### 2.1 GENERAL REQUIREMENTS

In each of the standards referred to herein, consider the advisory provisions to be mandatory, as though the word "shall" wherever it appears. Interpret reference in these standards to the "authority having jurisdiction", or words of similar meaning, to mean the Construction Engineer.

#### 2.1 PRODUCTS

# 2.1.1 Conduits and Fittings:

- 1. All conduits shall be unplasticized Polyvinyl Chloride (uPVC) in heavy wall schedule unless indicated on plans.
- 2. EMT or IMC conduits shall be used in sizes 15mm, 20mm and 25mm diameters for indoor installations where PVC is not specified.

# 2.1.2 Outlets, Boxes and Fittings:

- 1. At all outlets of whatever kind, for all systems, there shall be provided suitable fitting, which shall be either a box or other device especially designed to receive the type of fitting to be mounted thereon.
- 2. At all outlets on concealed conduit work, provide galvanized pressed steel outlet boxes of standard make. These boxes shall be in all cases standard and where such boxes are not available on the market, special boxes shall be secured by the contractor at his own expense.



In general outlet boxes shall be at least 100 mm in diameter, 53mm deep and No. 16 minimum gauge.

# 2.1.3 Junction and Pull boxes:

- 1. Junction and pull boxes, of Code gauge steel, galvanized shall be provided as indicated or as required for facilitating the pulling of wires and cables. Pull boxes in finished places shall be located and installed with permission and to the satisfaction of the Construction Engineer.
- All junction and pull boxes on exposed conduit work shall be provided with hubs for threaded pipe entry and covers provided with neoprene gaskets.

#### 2.3.4 Wires and Cables:

- 1. All wires shall be copper, soft-drawn and annealed, shall be of 98% conductivity, shall be smooth and true of a cylindrical form and shall be within 1% of the actual size called for.
- 2. All wires and cables shall comply with the requirements of the Underwriters Laboratories, the ASTM and ICEA as they apply to the particular usage.
- 3. All wires and cables shall be any quality brand or approved equal.
- 4. Wires and cables for power and lighting system shall be plastic insulated for 600 volts working pressure type "TW" unless otherwise noted on plans or specified.
- 5. Wires and cables for lighting systems installed or run throughout within the ballast compartment shall be plastic insulated for 600 volts working pressure type "THW" unless otherwise noted on plans or specified.
- 6. THHN/THWN wires can be used for the same size of wires provided the allowable current does not exceed that of TW/THW wires.

#### 2.3.5 Wall Switches and Plates:

- 1. Wall switches shall be rated with ampere and voltage ratings as required. Switches shall be for flush mounting type and of the quiet type, spring operated. The type of switches shall be tumbler operation and the color, plating and appearance of wall plates shall be selected by the Consultants. Appropriate samples shall be submitted prior to the purchase of wall switches and face plates. Switches and plates shall be any quality brand, or approved equal.
- 2. All Utility boxes intended for switch devices shall be specially designed to receive the particular type of switch device to be mounted and should be deep enough to accept and fit the total number of conductors required as per drawings.

# 2.3.6 Wall Receptacles and Plates:

1. Receptacle outlets shall be 15 Ampere, 250 V, 2 pole, 3-wire parallel slot, grounding type. Parallel slot outlet rated 15A, 125V grounded type shall be acceptable for use with 250V system. Locking type and other special purpose receptacle outlets shall be as indicated in the drawings.



Receptacle outlet and plates shall be as manufactured by any quality brand or approved equal.

- 2. Type and Color of receptacle outlet and plates shall be as selected by the Construction Architect/Engineer. Appropriate samples of outlets and plates shall be submitted prior to purchase of devices.
- 3. All utility boxes intended for receptacle outlet devices shall be specially designed to receive the particular type of receptacle outlet device to be mounted and should be deep enough to accept and fit the total number of conductors as required as per drawings.

#### 2.3.7 Panels:

- 1. Standard panels and cabinets, as much as possible shall be used and assembled on job. All panels shall be dead front construction, furnished with trims for surface mounting. Cabinets shall be of Code gauge with gutters at least 100 mm wider if necessary. The trim for all panels shall be finished in industrial grey enamel over a coat of trust inhibitor.
- 2. Lighting panels shall be equipped with branch air circuit breakers as required and mains as noted on Plans or panel schedule. All circuit breakers shall be any quality brand, or approved equal.

#### 2.3.7 Individual Breakers and Switches:

- Provide individual circuit breakers, safety switches and disconnect switches where indicated on plans. Voltage ratings shall be suitable in each case of service application. Enclosures shall be General Purpose, NEMA Type 1, except where specifically noted on plans or assembled on panel cabinets.
- 2. Circuit breakers shall consist of quick-make, quick-break type entirely trip-free operating mechanism with contacts, arc-interrupter, and thermal magnetic trip unit shall provide time-delayed overload protection, and in case of overload or short circuit current in any one pole. Circuit breaker shall be trip indicating, with the tripped position of breaker handle midway between "ON" and "OFF" positions.
- 3. All circuit breakers shall be bolt-on type unless noted otherwise. Plugin circuit breakers are not acceptable.

# SECTION 3 EXECUTION

# 3.1 GENERAL REQUIREMENTS:

Electrical installations shall conform to the requirements of the Code and to the requirements specified herein.

# 3.2 WIRING METHODS:

Wiring method shall be insulated conductors installed, except where specifically indicated or specified otherwise, or required by the Code to be installed otherwise. An insulated equipment grounding conductor shall be provided in all branch circuits, including lighting circuits.

3.3 CONDUITS INSTALLTION:



Unless indicated otherwise, conceal, conduit within finished wall, and floor. Install conduit panel with or at right angles to ceilings, walls, and structural members where located above accessible ceilings and where conduit will be visible after completion of project.

- 1. Where conduits rise through floor slabs, the curved portion of bends shall not be visible the finish slab.
- 2. Conduit Support: Support conduit by pipe straps, wall brackets, hangers or ceiling trapeze. Fasten by machine screws, welded threaded studs, or spring-tension clamps on steel works. Do not weld conduits or pipe straps to steel structures. The load applied to fasteners shall not exceed one-fourth of the proof test load. In partitions of light steel construction, use sheet-metal screws.
- 3. Make changes in direction of runs with symmetrical bends or castmetal fittings. Make field-made bends and offsets with hickey or conduit-bending machine. Do not install crushed or deformed conduits. Avoid trapped conduits. Prevent plaster, dirt, or trash from lodging in conduits, boxes, fittings, and equipment during construction. Free clogged conduits of all obstructions.
- 4. Install pull wires in empty conduits in which wire is to be installed. The pull wire shall be No. 14 AWG zinc-coated steel or plastic having not less than 200-pound tensile strength. Leave not less than 300 mm of slack at each end of the pull wires.
- 5. Conduit installed in Concrete Floor Slabs Locate so as not to adversely affect the structural strength of the slabs. Install conduit within the middle one-third of the concrete slab. Space conduits horizontally not closer than three diameters except at cabinet locations. Curved portions of bends shall not be visible above the finish slab. Increase slab thickness as necessary to provide a minimum 25 mm cover over conduit. Where embedded conduits cross expansion joints, provide suitable watertight expansion fittings and bonding jumpers. Conduits larger than 25 mm trade size shall be parallel with or at right angles to the main reinforcement, the conduit shall be close to one of the supports of the slab.
- 6. Fasten conduits to sheet metal boxes and cabinets with two lockouts where required by the code, where insulated bushings are used, and where bushings cannot be brought into firm contact with the box; otherwise, use at least a single lockout and bushing. Lockouts shall be the type with sharp edges for digging into the wall of metal enclosures. Install bushings on the ends of conduits and provide insulating type where required by Code.

#### 3.4 SPLICES:

Make splices in accessible locations. Make splices in conductors 5.5 mm2 and smaller with an insulated pressure type connector. Make splices in conductors



8mm2 and larger with a solderless connector and cover with an insulation material equivalent to the conductor.

#### **SECTION 4 LIGHTING SYSTEMS**

# 4.1 SCOPE OF WORK:

The work includes supply and installation of lighting fixtures.

#### 4.2 SUBMITTALS:

- 1. Data, shop drawings, and reports shall employ the terminology, classifications, and method prescribed by the IES Lighting Handbook, applicable, for the lighting system specified.
- 2. Manufacturer's Data Lighting fixtures, including lamps and ballast.

#### 4.3 PRODUCTS:

#### 4.3.1 Fluorescent Lamps:

Provide the number, type, and wattage indicated in the fixture schedule.

# 4.3.2 Florescent Ballasts:

Ballast shall be electronic type and shall be designed to operate on voltage system to which they are connected. Ballast shall have sound rating "A". Fixtures and ballast shall be designed and constructed to limit the ballast case temperature to 90 degrees Celsius © when installed in an ambient temperature of 40 degrees C.

4.3.3 All fluorescent ballast shall be U.L. approved rapid start and energy saving type. Submit data and information for approval of the Owner of Construction Architect/Engineer.

#### 4.3.3 Incandescent Lamps

Provide the number, type and wattage indicated or as required.


# 4.4 EXECUTION


# 4.4.1 Installation


Set lighting fixtures plumb, square and level with ceiling and walls, in alignment with adjacent lighting fixtures, and secure in accordance with manufacturer's directions and approved shop drawings. Mounting heights specified or indicated shall be bottom of fixtures for ceiling mounted fixtures and to center of fixture wall-mounted fixtures.


## 4.4.2 Grounding

Grounding noncurrent-carrying parts of equipment. Where the copper grounding conductor is connected to a metal other than copper, provide specially treated or lined connectors suitable for this purpose.



























**PDSWD** 

ADMINISTRATIVE DIVISION FIELD OFFICE CAR DSWD-AS-GF-058 | REV 02 | 07 OCT 2022

PROJECT NAME :

RENOVATION OF SANITARY SYSTEM
OF DSWD FO CAR TRAINING CENTER
COMPOUND

LOCATION :

ENGINEER'S HILL, BAGUIO CITY

SHEET CONTENT :

AS SHOWN

MARIA A CATBAGAN APLATEN, PhD

Regional Director

CONFORMED BY

RINA CLAIRE L. REYES

CAO, Concurrent AD Chief and OIC ARD FOR ADMINISTRATION

CHECKED BY

AO I, BGMS Head

PREPARED/DESIGNED BY

ENGRARIDA. REAMICO

PROJECT/TA No:

DATE SUBMITTED:

26 NOVEMBER 2024

DATE DESCRIPTION/REMARKS BY

LAN CATEGORY SHEET NUMBER

L 04/04

## **Checklist of Technical and Financial Documents**

### I. TECHNICAL COMPONENT ENVELOPE

### Class "A" Documents

<u>Legal D</u>	<u>ocuments</u>
□ (a) '	Valid PhilGEPS Registration Certificate (Platinum Membership) (all pages) in accordance with Section 8.5.2 of the IRR;
<u>Technic</u>	al Documents
c	Statement of the prospective bidder of all its ongoing government and private ontracts, including contracts awarded but not yet started, if any, whether similar or not similar in nature and complexity to the contract to be bid; <b>and</b>
□ (c)	Statement of the bidder's Single Largest Completed Contract (SLCC) similar to the contract to be bid, except under conditions provided under the rules; <b>and</b>
□ (d)	Special PCAB License in case of Joint Ventures <b>and</b> registration for the type and cost of the contract to be bid; <b>and</b>
□ (e)	Original copy of Bid Security. If in the form of a Surety Bond, submit also a certification issued by the Insurance Commission <u>or</u> original copy of Notarized Bid Securing Declaration; <u>and</u>
(f)	Project Requirements, which shall include the following:
	a. Organizational chart for the contract to be bid;
	b. List of contractor's key personnel ( <i>e.g.</i> , Project Manager, Project Engineers, Materials Engineers, and Foremen), to be assigned to the contract to be bid, with their complete qualification and experience data;
	c. List of contractor's major equipment units, which are owned, leased, and/or under purchase agreements, supported by proof of ownership or certification of availability of equipment from the equipment lessor/vendor
	for the duration of the project, as the case may be; d. Certificate of Site Inspection duly signed by the Building and Ground Management Section Head; and

	(g)	Original duly signed Omnibus Sworn Statement (OSS) <u>and</u> if applicable, Original Notarized Secretary's Certificate in case of a corporation, partnership, or cooperative; or Original Special Power of Attorney of all members of the joint venture giving full power and authority to its officer to sign the OSS and do acts to represent the Bidder.
Fin	nancia	l Documents
		The prospective bidder's computation of Net Financial Contracting Capacity (NFCC).
		Class "B" Documents
	(i) If a	pplicable, duly signed joint venture agreement (JVA) in accordance with RA No. 4566 and its IRR in case the joint venture is already in existence <u>or</u> duly notarized statements from all the potential joint venture partners stating that they will enter into and abide by the provisions of the JVA in the instance that the bid is successful.
II. FIN	IANC	IAL COMPONENT ENVELOPE
	(j) Ori	ginal of duly signed and accomplished Financial Bid Form; and
<u>Oth</u>	her do	cumentary requirements under RA No. 9184
	(k)	Original of duly signed Bid Prices in the Bill of Quantities; and
uni	it price	y accomplished Detailed Estimates Form, including a summary sheett indicating the es of construction materials, labor rates, and equipment rentals used in coming up Bid; $\underline{\mathbf{and}} \square$ (m) Cash Flow by Quarter.

# STATEMENT OF ALL ITS ON-GOING GOVERNMENT AND PRIVATE CONTRACTS, INCLUDING CONTRACTS AWARDED BUT NOT YET STARTED, IF ANY, WHETHER SIMILAR OR NOT SIMILAR IN NATURE AND COMPLEXITY TO THE CONTRACT TO BE BID

Name of the Contract or Title of the Project	Owner's Name and Address	Nature of Work / Scope of Work	Contractor's Role and percentage of participation	Date of Contract	Total Contract Value at Award	Value of Outstanding Works	Contract Duration		ge (%) of lishment		ted Time of npletion
								Planned	Actual	Start	Completion
A) Government Contracts											
i. On-going											
ii. Awarded but not yet started											
B) Private Contracts											
i. On-going											
ii. Awarded but not yet started											
Name of Firm / Applicant	-		Authorized Sig	natorv					Date		

### **Statement of Single Largest Similar Completed Contract**

Business Address :											
Name of Contract/Title o the Project	<ul><li>a. Owner's Name</li><li>b. Address</li><li>c. Telephone Nos.</li></ul>	Date of the Contract	Contract Duration	Scope of	Contractor's Role (Whether sole contractor, subcontractor, or partner in a JV)		Total Contract Value at Award	Date of Completion	Total contract value at completion	Percentage of Planned and Actual Accomplishments if applicable	
		Contract			Description	Percentage of Participation (%)				Planned	Actual
Government Contracts											
Private Contracts											
Total Cost											
Note: This statement shall be su	upported with the follow	ving documen	ts to be subm	nitted to the	Technical Worl	king Group durin	g the Post Qu	ualification Stag	e:	1	
<ol> <li>Notice to Proceed and</li> <li>Owner's Certificate of Performance Evaluation</li> <li>In case of contracts w</li> </ol>	Final Acceptance iss on System (CPES).	sued by the	-				l rating of	at least <b>Satis</b>	<b>factory</b> in the	e Construct	ors:
Submitted by		:_				·					
Designation		:_	(Printed Na	ıme & Signat	ure) 						
Date		:_									

### **Bid Securing Declaration Form**

[shall be submitted with the Bid if bidder opts to provide this form of bid security]

<b>REPUBLIC</b>	OF THE	PHILIPPINES)	CITY
OF		) S.S.	

# BID SECURING DECLARATION Project Identification No.: [Insert number]

To: [Insert name and address of the Procuring Entity]

I/We, the undersigned, declare that:

- 1. I/We understand that, according to your conditions, bids must be supported by a Bid Security, which may be in the form of a Bid Securing Declaration.
- 2. I/We accept that: (a) I/we will be automatically disqualified from bidding for any procurement contract with any procuring entity for a period of two (2) years upon receipt of your Blacklisting Order; and, (b) I/we will pay the applicable fine provided under Section 6 of the Guidelines on the Use of Bid Securing Declaration, within fifteen (15) days from receipt of the written demand by the procuring entity for the commission of acts resulting to the enforcement of the bid securing declaration under Sections 23.1(b), 34.2, 40.1 and 69.1, except 69.1(f),of the IRR of RA No. 9184; without prejudice to other legal action the government may undertake.
- 3. I/We understand that this Bid Securing Declaration shall cease to be valid on the following circumstances:
  - a. Upon expiration of the bid validity period, or any extension thereof pursuant to your request:
  - b. I am/we are declared ineligible or post-disqualified upon receipt of your notice to such effect, and (i) I/we failed to timely file a request for reconsideration or (ii) I/we filed a waiver to avail of said right; and
  - c. I am/we are declared the bidder with the Lowest Calculated Responsive Bid, and I/we have furnished the performance security and signed the Contract.

IN WITNESS WHEREOF, I/We have hereunto set my/our hand/s this \_\_\_\_ day of [month] [year] at [place of execution].

[Insert NAME OF BIDDER OR ITS AUTHORIZED REPRESENTATIVE]
[Insert signatory's legal capacity] Affiant

#### [Jurat]

[Format shall be based on the latest Rules on Notarial Practice]

Standard Form Number: SF-INFR-18

Revised on: July 29, 2004

### Statement of Availability of Key Personnel and Equipment

(Date)

### DIR. MARIA A. CATBAGAN-APLATEN, PhD

Regional Director DSWD-CAR 40 North Drive, Baguio City

Attention : The Chairperson

Bids and Awards Committee

Dear Sir:

In compliance with the requirements of the DSWD-CAR BAC for the bidding of the \_\_(Name of the Contract)\_\_, we certify that \_\_(Name of the Bidder)\_\_ has in its employ key personnel, such as project managers, project engineers, materials engineers and foremen, who may be engaged for the construction of the said contract.

Further, we likewise certify the availability of equipment that <u>(Name of the Bidder)</u> owns, has under lease, and/or has under purchase agreements, that may be used for the construction contracts.

Very truly yours,

(Name of Representative)
(Position)
(Name of Bidder)

Standard Form Number: SF-INFR-44 Revised

on: August 11, 2004

### **Contractor's Organizational Chart for the Firm**

Submit Copy of the Organizational Chart of the firm. Indicate in the chart the names of the Pro- Manager, Project Engineer, Bridge Engineer, Structural Engineer, Materials and Quality Cor- Engineer, Foreman and other Key Engineering Personnel.	
Attach the required Proposed Organizational Chart for the Contract as stated above	

(Name of Representative)

# (Position) (Name of Bidder)

Standard Form Number: SF-INFR-47

Revised on: August 11, 2004

# KEY PERSONNEL (FORMAT OF BIO-DATA)

Give the detailed information of the following personnel who are scheduled to be assigned as fulltime field staff for the project. Fill up a form for each person.

-	Authorized Managing Officer / Re	presentat	tive		
-	Sustained Technical Employee				
1.	Name	:			
2.	Date of Birth	:			
3.	Nationality	:			
4.	Education and Degrees	:			
5.	Specialty :				
6.	Registration	:			
7.	Length of Service with the Firm	:	Year from To	(months) (months)	
8.	Years of Experience	:			
9.	If Item 7 is less than ten (10) year or a ten (10)-year period (attach				ıployers
	Name and Address of Employer		<u>Length of Ser</u>	<u>vice</u>	
			year(s) from		
			year(s) from	to	
			year(s) from	to	

1.	Name	:					
2.	Name and Address of Owner	:					
3.	Name and Address of the Owner's Engineer (Consultant)	:					
4.	Indicate the Features of Project (particular interest connected with the project					and any oth	
5.	Contract Amount Expressed in Philippine Currency	:					
6.	Position	:					
7.	Structures for which the employed was responsible	e :					
8.	Assignment Period	:		(n			(years) (years)
 Nan	ne and Signature of Employee						
	hereby certified that the above perded to our company.	rsonnel	can be ass	signed to t	his project	t, if the con	tract is
	(Place and Date)			(Th	e Authoriz	zed Represe	ntative)

This should cover the past ten (10) years of experience. (Attached as many pages as necessary to show involvement of personnel in projects using the format below).

10. Experience:

Standard Form Number: SF-INFR-48 Revised on: August 11, 2004

### **Qualification of Key Personnel**

Business Name	·	 		
Business Address				
Dasiness / taaress	•			
	(For Ex.)			
	Project Manager /			
	(For Ex.) Project Manager / Engineer			
1				
Name				
2				
Address				
3				
Date of Birth				
4				
Employed Since				
5				
Experience				
6				
Previous				
Employment				
7				

Education				
8				
PRC License				
		·	·	
Minimum Requiremer	its:			
:		:	:	
Submitted by	:			
	(Printed Name	& Signature)		
Designation	:			
Date	:			

Standard Form Number: SF-INFR-49 Revised on: August 11, 2004

### List of Equipment, Owned or Leased and/or under Purchase Agreements

Business Name	:
Business Address	:

Description	Owned/ Leased/Under Purchase Agreement	Model/ Year	Capacity / Performance / Size	Plate No.	Motor No. / Body No.	Location	Condition	Proof of Ownership / Lessor or Vendor
1								
2.								
3.								
4.								
5.								
6.								
7.								
8.								
9.								
10.								
11.								
12.								
13.								
14.								
15.								

Submitted by	!	(Printed Name & Signature)
--------------	---	----------------------------

Designation	·
Date	<b>:</b>

Print as many pages as necessary.

### **Omnibus Sworn Statement (Revised)**

[shall be submitted with the Bid]

REPUBLIC OF THE PHILIPPINES	)
CITY/MUNICIPALITY OF	S.S.

### **AFFIDAVIT**

- I, [Name of Affiant], of legal age, [Civil Status], [Nationality], and residing at [Address of Affiant], after having been duly sworn in accordance with law, do hereby depose and state that:
- 1. [Select one, delete the other:]

[If a sole proprietorship:] I am the sole proprietor or authorized representative of [Name of Bidder] with office address at [address of Bidder];

[If a partnership, corporation, cooperative, or joint venture:] I am the duly authorized and designated representative of [Name of Bidder] with office address at [address of Bidder];

2. [Select one, delete the other:]

[If a sole proprietorship:] As the owner and sole proprietor, or authorized representative of [Name of Bidder], I have full power and authority to do, execute and perform any and all acts necessary to participate, submit the bid, and to sign and execute the ensuing contract for [Name of the Project] of the [Name of the Procuring Entity], as shown in the attached duly notarized Special Power of Attorney;

[If a partnership, corporation, cooperative, or joint venture:] I am granted full power and authority to do, execute and perform any and all acts necessary to participate, submit the bid, and to sign and execute the ensuing contract for [Name of the Project] of the [Name of the Procuring Entity], as shown in the attached [state title of attached document showing proof of authorization (e.g., duly notarized Secretary's Certificate, Board/Partnership Resolution, or Special Power of Attorney, whichever is applicable;)];

- 3. [Name of Bidder] is not "blacklisted" or barred from bidding by the Government of the Philippines or any of its agencies, offices, corporations, or Local Government Units, foreign government/foreign or international financing institution whose blacklisting rules have been recognized by the Government Procurement Policy Board, by itself or by relation, membership, association, affiliation, or controlling interest with another blacklisted person or entity as defined and provided for in the Uniform Guidelines on Blacklisting;
- 4. Each of the documents submitted in satisfaction of the bidding requirements is an authentic copy of the original, complete, and all statements and information provided therein are true and correct;
- 5. [Name of Bidder] is authorizing the Head of the Procuring Entity or its duly authorized representative(s) to verify all the documents submitted;
- 6. [Select one, delete the rest:]

[If a sole proprietorship:] The owner or sole proprietor is not related to the Head of the Procuring Entity, members of the Bids and Awards Committee (BAC), the Technical Working Group, and the BAC Secretariat, the head of the Project Management Office or the end-user unit, and the project consultants by consanguinity or affinity up to the third civil degree;

[If a partnership or cooperative:] None of the officers and members of [Name of Bidder] is related to the Head of the Procuring Entity, members of the Bids and Awards Committee (BAC), the Technical Working Group, and the BAC Secretariat, the head of the Project Management Office or the end-user unit, and the project consultants by consanguinity or affinity up to the third civil degree;

[If a corporation or joint venture:] None of the officers, directors, and controlling stockholders of [Name of Bidder] is related to the Head of the Procuring Entity, members of the Bids and Awards Committee (BAC), the Technical Working Group, and the BAC Secretariat, the head of the Project Management Office or the end-user unit, and the project consultants by consanguinity or affinity up to the third civil degree;

- 7. [Name of Bidder] complies with existing labor laws and standards; and
- 8. [Name of Bidder] is aware of and has undertaken the responsibilities as a Bidder in compliance with the Philippine Bidding Documents, which includes:
  - a. Carefully examining all of the Bidding Documents;
  - b. Acknowledging all conditions, local or otherwise, affecting the implementation of the Contract:
  - Making an estimate of the facilities available and needed for the contract to be bid, if any: and
  - d. Inquiring or securing Supplemental/Bid Bulletin(s) issued for the [Name of the Project].
- 9. [Name of Bidder] did not give or pay directly or indirectly, any commission, amount, fee, or any form of consideration, pecuniary or otherwise, to any person or official, personnel or representative of the government in relation to any procurement project or activity.
- 10. In case advance payment was made or given, failure to perform or deliver any of the obligations and undertakings in the contract shall be sufficient grounds to constitute criminal liability for Swindling (Estafa) or the commission of fraud with unfaithfulness or abuse of confidence through misappropriating or converting any payment received by a person or entity under an obligation involving the duty to deliver certain goods or services, to the prejudice of the public and the government of the Philippines pursuant to Article 315 of Act No. 3815 s. 1930, as amended, or the Revised Penal Code.

	the Revise	ed Penal Code.									
IN	WITNESS	WHEREOF, I	have	hereunto	set m	y han	d this	day	of,	20	at
		_, Philippines.									
				[Insert N.	AME C	F BIDI	DER OF	R ITS AU	JTHORIZ	ZED	
						EDDE	CENITA	TI\/ <b>[</b> ]			

REPRESENTATIVE] [Insert signatory's legal capacity] Affiant

#### [Jurat]

[Format shall be based on the latest Rules on Notarial Practice]

Standard Form Number: SF-GOOD-14

Name of Supplier / Distributor / Manufacturer

Signature of Authorized Representative

Revised on: May 24, 2004

### FINANCIAL DOCUMENTS FOR ELIGIBILITY CHECK

on t FY20	he ba )24, s	of the Applicant Supplier's/Distributor' asis of the income tax return and audit stamped "RECEIVED" by the Bureau of agent.	ed financial statement for FY2023 or
			Year 20
	1.	Total Assets	
	2.	Current Assets	
	3.	Total Liabilities	
	4.	Current Liabilities	
	5.	Net Worth (1-3)	
	6.	Net Working Capital (2-4)	
follo  NFCC =  or uncc  contract	ws: [(Cui mple s yet	rrent assets minus current liabilities) (1: ted portions of the projects under or to be started, coinciding with the contra	5)] minus the value of all outstanding awarded
	teme	nat the computation of the above is based nt for FY2022 or FY2023 stamped "REC	
Submitted b	y:		

Date :	
NOTE:	

1. If Partnership or Joint Venture, each Partner or Member Firm of Joint Venture shall submit the above requirements.

### **Bid Form for the Procurement of Infrastructure Projects**

[shall be submitted with the Bid]

BID FORM
Date :Project Identification No. :

To: [name and address of Procuring Entity]

Having examined the Philippine Bidding Documents (PBDs) including the Supplemental or Bid Bulletin Numbers *[insert numbers]*, the receipt of which is hereby duly acknowledged, we, the undersigned, declare that:

- a. We have no reservation to the PBDs, including the Supplemental or Bid Bulletins, for the Procurement Project: [insert name of contract];
- b. We offer to execute the Works for this Contract in accordance with the PBDs;
- c. The total price of our Bid in words and figures, excluding any discounts offered below is: [insert information];
- d. The discounts offered and the methodology for their application are: [insert information];
- e. The total bid price includes the cost of all taxes, such as, but not limited to: [specify the applicable taxes, e.g. (i) value added tax (VAT), (ii) income tax, (iii) local taxes, and (iv) other fiscal levies and duties], which are itemized herein and reflected in the detailed estimates.
- f. Our Bid shall be valid within the a period stated in the PBDs, and it shall remain binding upon us at any time before the expiration of that period;
- g. If our Bid is accepted, we commit to obtain a Performance Security in the amount of *[insert percentage amount]* percent of the Contract Price for the due performance of the Contract, or a Performance Securing Declaration in lieu of the the allowable forms of Performance Security, subject to the terms and conditions of issued GPPB guidelines<sup>1</sup> for this purpose;
- h. We are not participating, as Bidders, in more than one Bid in this bidding process, other than alternative offers in accordance with the Bidding Documents;
- We understand that this Bid, together with your written acceptance thereof included in your notification of award, shall constitute a binding contract between us, until a formal Contract is prepared and executed; and
- j. We understand that you are not bound to accept the Lowest Calculated Bid or any other Bid that you may receive.


-

<sup>&</sup>lt;sup>1</sup> currently based on GPPB Resolution No. 09-2020

- k. We likewise certify/confirm that the undersigned, is the duly authorized representative of the bidder, and granted full power and authority to do, execute and perform any and all acts necessary to participate, submit the bid, and to sign and execute the ensuing contract for the [Name of Project] of the [Name of the Procuring Entity].
- I. We acknowledge that failure to sign each and every page of this Bid Form, including the Bill of Quantities, shall be a ground for the rejection of our bid.

lame:	
egal Capacity:	
Signature:	
Ouly authorized to sign the Bid for and behalf of:	
Date:	

#### MARKING AND SEALING OF ENVELOPE:



Note: The technical and financial documents must be submitted in two (2) copies (Original Copy and Copy 1). The Original Technical Component envelope and Original Financial Component envelope must be sealed in one envelope marked "ORIGINAL BID". The Copy 1 Technical Component envelope and Copy 1 Financial Component Envelope must also be sealed in another envelope marked "Copy 1 Bid". These envelopes containing the Original Copy and Copy 1 must be enclosed in one single envelope marked "BIDDING DOCUMENTS". The technical and financial documents must be properly tabbed and signed.



### **CERTIFICATE OF SITE INSPECTION**

This is to certify that	of			
	ne of Representative) with office address			
(Name of				
at for the	had inspected the site			
located at _				
This certification is issued to Mr./Ms part	s as			
Technical Proposal.	(Name of Bidder or Representative) of his/her			
Issued this of,	2025.			

### **AR. GLYXTER RUDIO**

Administrative Officer I / BGMS Head

